

# Note: 000058

#### **Overview**

| Number      | 000058  |
|-------------|---|
| Description | BCS CSP03 Installation Test – FLTP Comparison Issue |
| Version     | 2 from 10.07.2017                                   |
| Status      | Released to Customer                                |
| Language    | EN  |
| Responsible | Markus Seng   |
| Product     | BCP   |
| Category    | Correction - PMC & GMC                              |

#### **Symptom**

You run the QuantityWare Installation Test for BCP 10B on CSP03 level in your development system in template client 045, in which the BC set /QTYW/BCP\_10B has been activated. After all test reports have been executed, the API MPMS Chapter 11.2.1(M) implementation test report issues an error message for a conversion group test. The Test Scenario Q080 also reports an error.

## Cause

Error message "/QTYW/QCI 060 : Obbserved or vapor pressure 1.46960000000000 E+01 is below base pressure 1.46960000000000 E+01 - UoM PSI" is causing this failure.

### **Solution**



This extended test scenario was introduced with BCS 10B CSP03. The appearance of this issue is database dependent. Some databases store and retrieve floating point values with a variation on the level of 1.000000000000E-13 accuracy only. Thus, the simple SAP ABAP comparison "IF A = B" may fail. With this code correction, the correct QuantityWare floating point comparison function is utilized for vapor pressure comparison functions.

## **Transport Reference**

| SAP Release | Transport  | File Name          | Notes |
|-------------|------------|--------------------|-------|
| ECC600      | QOIK900246 | NOTE-00058-600.SAR |       |
|             |            |                    |       |

## Validity

| SAP Release | From SP   | To SP | In SP Shipment |
|-------------|-----------|-------|----------------|
| ECC600      | 10B CSP03 | -     | BCS 3.0        |