



# QuantityWare Working Paper

## Annex A - Comparison of ASTM D1250 Standard Implementations

Detailed results for complete calculation grid



## Version History

Version	Date	Description
00	2010-12-17	Initial version
01	2021-06-23	Modern QW document style applied
02	2023-11-01	Editorial revision and confirmation



## Contents

<b>1. ASTM D1250-80 and ASTM D1250-04 - complete grid results.....</b>	<b>5</b>
1.1.    Table 5A – crude oil, 60 °F base temperature – detailed results.....	5
1.2.    Table 5B – products, 60 °F base temperature – detailed results .....	8
1.3.    Table 5D – lubricants, 60 °F base temperature – detailed results .....	10
1.4.    Table 23A – crude oil, 60 °F base temperature – detailed results.....	12
1.5.    Table 23B – products, 60 °F base temperature – detailed results .....	14
1.6.    Table 23D – lubricants, 60 °F base temperature – detailed results .....	16
1.7.    Table 53A – crude oil, 15 °C base temperature – detailed results .....	18
1.8.    Table 53B – products, 15 °C base temperature – detailed results.....	21
1.9.    Table 53D – lubricants, 15 °C base temperature – detailed results.....	24
1.10.    Table 59A – crude oil, 20 °C base temperature – detailed results.....	27
1.11.    Table 59B – products, 20 °C base temperature – detailed results .....	30
1.12.    Table 59D – lubricants, 20 °C base temperature – detailed results .....	33
1.13.    Table 6A – crude oil, 60 °F base temperature – detailed results .....	36
1.14.    Table 6B – products, 60 °F base temperature – detailed results.....	39
1.15.    Table 6C – special applications, 60 °F base temperature – detailed results.....	42
1.16.    Table 6D – lubricants, 60 °F base temperature – detailed results.....	45
1.17.    Table 24A – crude oil, 60 °F base temperature – detailed results .....	48
1.18.    Table 24B – products, 60 °F base temperature – detailed results.....	51
1.19.    Table 24C – special applications, 60 °F base temperature – detailed results.....	54
1.20.    Table 24D – lubricants, 60 °F base temperature – detailed results.....	57
1.21.    Table 54A – crude oil, 15 °C base temperature – detailed results.....	60
1.22.    Table 54B – products, 15 °C base temperature – detailed results .....	65
1.23.    Table 54D – lubricants, 15 °C base temperature – detailed results .....	70

1.24.	Table 60A – crude oil, 20 °C base temperature – detailed results.....	75
1.25.	Table 60B – products, 20 °C base temperature – detailed results .....	80
1.26.	Table 60D – lubricants, 20 °C base temperature – detailed results .....	85

# 1. ASTM D1250-80 and ASTM D1250-04 - complete grid results



## Editorial Note:

The decimal point and thousand separators for numbers and quantity values for this document are defined as follows: The decimal point is a comma ',', the thousand separator is a dot '.'. Example: 123.456.789,987

## 1.1. Table 5A – crude oil, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** -10 °API to 100 °API, increment 0,1 °API

**Quantity compared:** Base API gravity @ 60 °F

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$



**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.732.918	107.799	50.478	57.321	107.799	0	0,1	59,7	82,2
2	1.381.166	18.944	2.673	16.271	18.944	0	0,1	59,5	47,0
3	1.381.166	18.944	2.673	16.271	18.944	0	0,1	59,5	47,0
4	2.351.752	88.855	47.805	41.050	88.855	0	0,1	59,7	82,2
5	2.351.752	88.855	47.805	41.050	88.855	0	0,1	59,7	82,2

C	P	PG	PL	P1	PX	
1	2,9%	46,8%	53,2%	2,9%	0,0%	2004 R./2004 Inc.
2	1,4%	14,1%	85,9%	1,4%	0,0%	1980 R./2004 Inc.
3	1,4%	14,1%	85,9%	1,4%	0,0%	1980 R./1980 Inc.
4	3,8%	53,8%	46,2%	3,8%	0,0%	1980 Ext. R/2004 Inc.
5	3,8%	53,8%	46,2%	3,8%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.164.148	26.431	25.533	898	26.431	0	0,1	59,7	82,2
2	317.818	2.549	2.156	393	2.549	0	0,1	59,5	47,0
3	317.818	2.549	2.156	393	2.549	0	0,1	59,5	47,0
4	846.330	23.882	23.377	505	23.882	0	0,1	59,7	82,2
5	846.330	23.882	23.377	505	23.882	0	0,1	59,7	82,2

C	P	PG	PL	P1	PX	
1	2,3%	96,6%	3,4%	2,3%	0,0%	2004 R./2004 Inc.
2	0,8%	84,6%	15,4%	0,8%	0,0%	1980 R./2004 Inc.
3	0,8%	84,6%	15,4%	0,8%	0,0%	1980 R./1980 Inc.
4	2,8%	97,9%	2,1%	2,8%	0,0%	1980 Ext. R/2004 Inc.
5	2,8%	97,9%	2,1%	2,8%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.568.770	81.368	24.945	56.423	81.368	0	0,1	60,3	82,3
2	1.063.348	16.395	517	15.878	16.395	0	0,1	60,5	46,7
3	1.063.348	16.395	517	15.878	16.395	0	0,1	60,5	46,7
4	1.505.422	64.973	24.428	40.545	64.973	0	0,1	60,3	82,3
5	1.505.422	64.973	24.428	40.545	64.973	0	0,1	60,3	82,3

C	P	PG	PL	P1	PX	
1	2,3%	30,7%	69,3%	2,3%	0,0%	2004 R./2004 Inc.
2	1,5%	3,2%	96,8%	1,5%	0,0%	1980 R./2004 Inc.
3	1,5%	3,2%	96,8%	1,5%	0,0%	1980 R./1980 Inc.
4	4,3%	37,6%	62,4%	4,3%	0,0%	1980 Ext. R/2004 Inc.
5	4,3%	37,6%	62,4%	4,3%	0,0%	1980 Ext./1980 Inc.



## 1.2. Table 5B – products, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** -10 °API to 100 °API, increment 0,1 °API

**Quantity compared:** Base API gravity @ 60 °F

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.169.913	98.219	37.699	60.520	98.115	104	0,4	301,9	87,0
2	1.837.055	27.612	5.018	22.594	27.612	0	0,1	59,7	76,7
3	1.837.055	27.612	5.018	22.594	27.612	0	0,1	59,7	76,7
4	1.332.858	70.607	32.681	37.926	70.503	104	0,4	301,9	87,0
5	1.332.858	70.607	32.681	37.926	70.503	104	0,4	301,9	87,0

C	P	PG	PL	P1	PX				
1	3,1%	38,4%	61,6%	3,1%	0,0%	2004 R./2004 Inc.			
2	1,5%	18,2%	81,8%	1,5%	0,0%	1980 R./2004 Inc.			
3	1,5%	18,2%	81,8%	1,5%	0,0%	1980 R./1980 Inc.			
4	5,3%	46,3%	53,7%	5,3%	0,0%	1980 Ext. R/2004 Inc.			
5	5,3%	46,3%	53,7%	5,3%	0,0%	1980 Ext./1980 Inc.			

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	623.911	11.801	10.926	875	11.801	0	0,1	59,7	76,7
2	487.093	4.946	4.213	733	4.946	0	0,1	59,7	76,7
3	487.093	4.946	4.213	733	4.946	0	0,1	59,7	76,7
4	136.818	6.855	6.713	142	6.855	0	0,1	59,2	88,6
5	136.818	6.855	6.713	142	6.855	0	0,1	59,2	88,6

C	P	PG	PL	P1	PX				
1	1,9%	92,6%	7,4%	1,9%	0,0%	2004 R./2004 Inc.			
2	1,0%	85,2%	14,8%	1,0%	0,0%	1980 R./2004 Inc.			
3	1,0%	85,2%	14,8%	1,0%	0,0%	1980 R./1980 Inc.			
4	5,0%	97,9%	2,1%	5,0%	0,0%	1980 Ext. R/2004 Inc.			
5	5,0%	97,9%	2,1%	5,0%	0,0%	1980 Ext./1980 Inc.			

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.546.002	86.418	26.773	59.645	86.314	104	0,4	301,9	87
2	1.349.962	22.666	805	21.861	22.666	0	0,1	60,3	76,1
3	1.349.962	22.666	805	21.861	22.666	0	0,1	60,3	76,1
4	1.196.040	63.752	25.968	37.784	63.648	104	0,4	301,9	87
5	1.196.040	63.752	25.968	37.784	63.648	104	0,4	301,9	87

C	P	PG	PL	P1	PX				
1	3,4%	31,0%	69,0%	3,4%	0,0%	2004 R./2004 Inc.			
2	1,7%	3,6%	96,4%	1,7%	0,0%	1980 R./2004 Inc.			
3	1,7%	3,6%	96,4%	1,7%	0,0%	1980 R./1980 Inc.			
4	5,3%	40,7%	59,3%	5,3%	0,0%	1980 Ext. R/2004 Inc.			
5	5,3%	40,7%	59,3%	5,3%	0,0%	1980 Ext./1980 Inc.			



### 1.3. Table 5D – lubricants, 60 °F base temperature – detailed results

#### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** -10 °API to 45 °API, increment 0,1 °API

**Quantity compared: Base API gravity @ 60 °F**

#### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

#### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.814.635	52.991	37.131	15.86	52.991	0	0,1	59,3	38,7
2	1.524.420	45.836	30.213	15.623	45.836	0	0,1	59,3	38,7
3	1.524.420	45.836	30.213	15.623	45.836	0	0,1	59,3	38,7
4	290.215	7.155	6.918	237	7.155	0	0,1	-0,1	-9,0
5	290.215	7.155	6.918	237	7.155	0	0,1	-0,1	-9,0

C	P	PG	PL	P1	PX	
1	2,9%	70,1%	29,9%	2,9%	0,0%	2004 R./2004 Inc.
2	3,0%	65,9%	34,1%	3,0%	0,0%	1980 R./2004 Inc.
3	3,0%	65,9%	34,1%	3,0%	0,0%	1980 R./1980 Inc.
4	2,5%	96,7%	3,3%	2,5%	0,0%	1980 Ext. R/2004 Inc.
5	2,5%	96,7%	3,3%	2,5%	0,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	598.37	14.122	13.727	395	14.122	0	0,1	59,3	38,7
2	316.762	7.325	6.981	344	7.325	0	0,1	59,3	38,7
3	316.762	7.325	6.981	344	7.325	0	0,1	59,3	38,7
4	281.608	6.797	6.746	51	6.797	0	0,1	-0,1	-9,0
5	281.608	6.797	6.746	51	6.797	0	0,1	-0,1	-9,0

C	P	PG	PL	P1	PX	
1	2,4%	97,2%	2,8%	2,4%	0,0%	2004 R./2004 Inc.
2	2,3%	95,3%	4,7%	2,3%	0,0%	1980 R./2004 Inc.
3	2,3%	95,3%	4,7%	2,3%	0,0%	1980 R./1980 Inc.
4	2,4%	99,2%	0,8%	2,4%	0,0%	1980 Ext. R/2004 Inc.
5	2,4%	99,2%	0,8%	2,4%	0,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.216.265	38.869	23.404	15.465	38.869	0	0,1	60,7	38,7
2	1.207.658	38.511	23.232	15.279	38.511	0	0,1	60,7	38,7
3	1.207.658	38.511	23.232	15.279	38.511	0	0,1	60,7	38,7
4	8.607	358	172	186	358	0	0,1	300,1	3,3
5	8.607	358	172	186	358	0	0,1	300,1	3,3

C	P	PG	PL	P1	PX	
1	3,2%	60,2%	39,8%	3,2%	0,0%	2004 R./2004 Inc.
2	3,2%	60,3%	39,7%	3,2%	0,0%	1980 R./2004 Inc.
3	3,2%	60,3%	39,7%	3,2%	0,0%	1980 R./1980 Inc.
4	4,2%	48,0%	52,0%	4,2%	0,0%	1980 Ext. R/2004 Inc.
5	4,2%	48,0%	52,0%	4,2%	0,0%	1980 Ext./1980 Inc.



## 1.4. Table 23A – crude oil, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** 0,6112 relative density to 1,1646 relative density, increment 0,0001 relative density

**Quantity compared:** Base relative density @ 60 °F

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	18.676.835	14.845.465	7.692.392	7.153.073	7.687.014	7.158.451	0,0003	59,9	0,6323
2	9.701.826	7.717.658	3.974.823	3.742.835	3.973.597	3.744.061	0,0003	59,9	0,6323
3	1.940.189	132.568	110.995	21.573	132.568	0	0,0001	59,9	0,6325
4	8.975.009	7.127.807	3.717.569	3.410.238	3.713.417	3.414.390	0,0003	59,5	1,1073
5	1.794.938	204.802	155.646	49.156	204.802	0	0,0001	59,5	1,1075

C	P	PG	PL	P1	PX	
1	79,5%	51,8%	48,2%	41,2%	38,3%	2004 R./2004 Inc.
2	79,5%	51,5%	48,5%	41,0%	38,6%	1980 R./2004 Inc.
3	6,8%	83,7%	16,3%	6,8%	0,0%	1980 R./1980 Inc.
4	79,4%	52,2%	47,8%	41,4%	38,0%	1980 Ext. R/2004 Inc.
5	11,4%	76,0%	24,0%	11,4%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.150.843	4.951.924	2.425.555	2.526.369	2.402.190	2.549.734	0,0003	59,9	0,6323
2	2.746.516	2.204.688	1.088.288	1.116.400	1.083.653	1.121.035	0,0003	59,9	0,6323
3	549.307	21.565	2.043	19.522	21.565	0	0,0001	59,9	0,6325
4	3.404.327	2.747.236	1.337.267	1.409.969	1.318.537	1.428.699	0,0003	59,5	11,073
5	681.101	49.222	696	48.526	49.222	0	0,0001	59,5	11,075

C	P	PG	PL	P1	PX	
1	80,5%	49,0%	51,0%	39,1%	41,5%	2004 R./2004 Inc.
2	80,3%	49,4%	50,6%	39,5%	40,8%	1980 R./2004 Inc.
3	3,9%	9,5%	90,5%	3,9%	0,0%	1980 R./1980 Inc.
4	80,7%	48,7%	51,3%	38,7%	42,0%	1980 Ext. R/2004 Inc.
5	7,2%	1,4%	98,6%	7,2%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	12.525.992	9.893.541	5.266.837	4.626.704	5.284.824	4.608.717	0,0003	60,1	0,6232
2	6.955.310	5.512.970	2.886.535	2.626.435	2.889.944	2.623.026	0,0003	60,1	0,6232
3	1.390.882	111.003	108.952	2.051	111.003	0	0,0001	60,1	0,6230
4	5.570.682	4.380.571	2.380.302	2.000.269	2.394.880	1.985.691	0,0003	60,5	10,992
5	1.113.837	155.58	154.95	630	155.58	0	0,0001	60,5	10,990

C	P	PG	PL	P1	PX	
1	79,0%	53,2%	46,8%	42,2%	36,8%	2004 R./2004 Inc.
2	79,3%	52,4%	47,6%	41,6%	37,7%	1980 R./2004 Inc.
3	8,0%	98,2%	1,8%	8,0%	0,0%	1980 R./1980 Inc.
4	78,6%	54,3%	45,7%	43,0%	35,6%	1980 Ext. R/2004 Inc.
5	14,0%	99,6%	0,4%	14,0%	0,0%	1980 Ext./1980 Inc.



## 1.5. Table 23B – products, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** 0,6112 relative density to 1,1646 relative density, increment 0,0001 relative density

**Quantity compared:** Base relative density @ 60 °F

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	18.478.116	14.666.464	7.582.618	7.083.846	7.538.094	7.128.370	0,0015	301,8	0,6477
2	8.597.176	6.854.708	3.517.663	3.337.045	3.474.549	3.380.159	0,0003	59,9	0,6618
3	1.719.410	118.556	99.639	18.917	118.556	0	0,0001	59,9	0,6620
4	9.880.940	7.811.756	4.064.955	3.746.801	4.063.545	3.748.211	0,0015	301,8	0,6477
5	1.975.964	250.817	191.07	59.747	248.944	1.873	0,0013	301,7	0,6480

C	P	PG	PL	P1	PX	
1	79,4%	51,7%	48,3%	40,8%	38,6%	2004 R./2004 Inc.
2	79,7%	51,3%	48,7%	40,4%	39,3%	1980 R./2004 Inc.
3	6,9%	84,0%	16,0%	6,9%	0,0%	1980 R./1980 Inc.
4	79,1%	52,0%	48,0%	41,1%	37,9%	1980 Ext. R/2004 Inc.
5	12,7%	76,2%	23,8%	12,6%	0,1%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.150.595	4.937.467	2.410.537	2.526.930	2.412.794	2.524.673	0,0005	-49,9	0,8318
2	2.505.325	2.008.070	990.713	1.017.357	991.163	1.016.907	0,0003	59,9	0,6618
3	501.065	19.115	2.143	16.972	19.115	0	0,0001	59,9	0,6620
4	3.645.270	2.929.397	1.419.824	1.509.573	1.421.631	1.507.766	0,0005	-49,9	0,8318
5	729.289	53.069	804	52.265	53.069	0	0,0001	59,9	0,6430

C	P	PG	PL	P1	PX	
1	80,3%	48,8%	51,2%	39,2%	41,0%	2004 R./2004 Inc.
2	80,2%	49,3%	50,7%	39,6%	40,6%	1980 R./2004 Inc.
3	3,8%	11,2%	88,8%	3,8%	0,0%	1980 R./1980 Inc.
4	80,4%	48,5%	51,5%	39,0%	41,4%	1980 Ext. R/2004 Inc.
5	7,3%	1,5%	98,5%	7,3%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	12.327.521	9.728.997	5.172.081	4.556.916	5.125.300	4.603.697	0,0015	301,8	0,6477
2	6.091.851	4.846.638	2.526.950	2.319.688	2.483.386	2.363.252	0,0003	60,1	0,6537
3	1.218.345	99.441	97.496	1.945	99.441	0	0,0001	60,1	0,6535
4	6.235.670	4.882.359	2.645.131	2.237.228	2.641.914	2.240.445	0,0015	301,8	0,6477
5	1.246.675	197.748	190.266	7.482	195.875	1.873	0,0013	301,7	0,6480

C	P	PG	PL	P1	PX	
1	78,9%	53,2%	46,8%	41,6%	37,3%	2004 R./2004 Inc.
2	79,6%	52,1%	47,9%	40,8%	38,8%	1980 R./2004 Inc.
3	8,2%	98,0%	2,0%	8,2%	0,0%	1980 R./1980 Inc.
4	78,3%	54,2%	45,8%	42,4%	35,9%	1980 Ext. R/2004 Inc.
5	15,9%	96,2%	3,8%	15,7%	0,2%	1980 Ext./1980 Inc.



## 1.6. Table 23D – lubricants, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Observed density:** 0,8017 relative density to 1,1646 relative density, increment 0,0001 relative density

**Quantity compared:** Base relative density @ 60 °F

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	11.791.560	9.432.517	4.842.679	4.589.838	4.718.018	4.714.499	0,0003	59,0	0,8057
2	9.797.679	7.837.702	4.069.737	3.767.965	3.919.825	3.917.877	0,0003	59,0	0,8057
3	1.959.175	176.715	162.978	13.737	176.715	0	0,0001	59,0	0,8055
4	1.993.881	1.594.815	772.942	821.873	798.193	796.622	0,0003	65,3	11,627
5	398.893	28.036	2.505	25.531	28.036	0	0,0001	65,3	11,625

C	P	PG	PL	P1	PX	
1	80,0%	51,3%	48,7%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	51,9%	48,1%	40,0%	40,0%	1980 R./2004 Inc.
3	9,0%	92,2%	7,8%	9,0%	0,0%	1980 R./1980 Inc.
4	80,0%	48,5%	51,5%	40,0%	40,0%	1980 Ext. R/2004 Inc.
5	7,0%	8,9%	91,1%	7,0%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.042.329	3.233.480	1.581.391	1.652.089	1.617.702	1.615.778	0,0003	59,0	0,8057
2	2.115.103	1.691.946	836.034	855.912	846.325	845.621	0,0003	59,0	0,8057
3	423.14	14.468	2.236	12.232	14.468	0	0,0001	59,0	0,8055
4	1.927.226	1.541.534	745.357	796.177	771.377	770.157	0,0003	-0,1	10,263
5	385.562	25.662	132	25.53	25.662	0	0,0001	-0,1	10,265

C	P	PG	PL	P1	PX	
1	80,0%	48,9%	51,1%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	49,4%	50,6%	40,0%	40,0%	1980 R./2004 Inc.
3	3,4%	15,5%	84,5%	3,4%	0,0%	1980 R./1980 Inc.
4	80,0%	48,4%	51,6%	40,0%	40,0%	1980 Ext. R/2004 Inc.
5	6,7%	0,5%	99,5%	6,7%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.749.231	6.199.037	3.261.288	2.937.749	3.100.316	3.098.721	0,0003	61	0,8018
2	7.682.576	6.145.756	3.233.703	2.912.053	3.073.500	3.072.256	0,0003	61	0,8018
3	1.536.035	162.247	160.742	1.505	162.247	0	0,0001	61	0,8020
4	66.655	53.281	27.585	25.696	26.816	26.465	0,0003	65,3	11,627
5	13.331	2.374	2.373	1	2.374	0	0,0001	65,3	11,625

C	P	PG	PL	P1	PX	
1	80,0%	52,6%	47,4%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	52,6%	47,4%	40,0%	40,0%	1980 R./2004 Inc.
3	10,6%	99,1%	0,9%	10,6%	0,0%	1980 R./1980 Inc.
4	79,9%	51,8%	48,2%	40,2%	39,7%	1980 Ext. R/2004 Inc.
5	17,8%	100,0%	0,0%	17,8%	0,0%	1980 Ext./1980 Inc.



## 1.7. Table 53A – crude oil, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 611,2 kg/m<sup>3</sup> to 1.163,8 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 15 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

Results ASTM D1250-80 standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.724.705	16.480.191	8.813.893	7.666.298	8.489.214	7.990.977	0,3	14,95	613,8
2	8.436.355	6.708.254	3.554.571	3.153.683	3.456.169	3.252.085	0,3	14,80	818,3
3	1.687.271	213.33	194.124	19.206	213.33	0	0,1	14,80	818,5
4	12.288.350	9.771.937	5.259.322	4.512.615	5.033.045	4.738.892	0,3	14,95	613,8
5	2.456.872	507.124	409.264	97.86	507.124	0	0,1	14,95	614,0

C	P	PG	PL	P1	PX	
1	79,5%	53,5%	46,5%	41,0%	38,6%	2004 R./2004 Inc.
2	79,5%	53,0%	47,0%	41,0%	38,5%	1980 R./2004 Inc.
3	12,6%	91,0%	9,0%	12,6%	0,0%	1980 R./1980 Inc.
4	79,5%	53,8%	46,2%	41,0%	38,6%	1980 Ext. R/2004 Inc.
5	20,6%	80,7%	19,3%	20,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.770.665	5.454.229	2.628.913	2.825.316	2.632.734	2.821.495	0,3	14,95	613,8
2	2.066.595	1.658.390	812.551	845.839	816.423	841.967	0,3	14,80	818,3
3	413.319	19.209	5	19.204	19.209	0	0,1	14,80	818,5
4	4.704.070	3.795.839	1.816.362	1.979.477	1.816.311	1.979.528	0,3	14,95	613,8
5	940.556	97.861	7	97.854	97.861	0	0,1	14,95	614,0

C	P	PG	PL	P1	PX	
1	80,6%	48,2%	51,8%	38,9%	41,7%	2004 R./2004 Inc.
2	80,2%	49,0%	51,0%	39,5%	40,7%	1980 R./2004 Inc.
3	4,6%	0,0%	100,0%	4,6%	0,0%	1980 R./1980 Inc.
4	80,7%	47,9%	52,1%	38,6%	42,1%	1980 Ext. R/2004 Inc.
5	10,4%	0,0%	100,0%	10,4%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.954.040	11.025.962	6.184.980	4.840.982	5.856.480	5.169.482	0,3	15,05	614,2
2	6.369.760	5.049.864	2.742.020	2.307.844	2.639.746	2.410.118	0,3	15,20	818,2
3	1.273.952	194.121	194.119	2	194.121	0	0,1	15,20	818,0
4	7.584.280	5.976.098	3.442.960	2.533.138	3.216.734	2.759.364	0,3	15,05	614,2
5	1.516.316	409.263	409.257	6	409.263	0	0,1	15,05	614,0

C	P	PG	PL	P1	PX	
1	79,0%	56,1%	43,9%	42,0%	37,0%	2004 R./2004 Inc.
2	79,3%	54,3%	45,7%	41,4%	37,8%	1980 R./2004 Inc.
3	15,2%	100,0%	0,0%	15,2%	0,0%	1980 R./1980 Inc.
4	78,8%	57,6%	42,4%	42,4%	36,4%	1980 Ext. R/2004 Inc.
5	27,0%	100,0%	0,0%	27,0%	0,0%	1980 Ext./1980 Inc.

Results ASTM D1250-80 with "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.724.705	3.605.133	3.018.445	586.688	3.605.133	0	0,1	14,95	613,8
2	8.436.330	1.067.931	971.572	96.359	1.067.931	0	0,1	14,80	818,2
3	8.436.330	1.067.931	971.572	96.359	1.067.931	0	0,1	14,80	818,2
4	12.288.375	2.537.202	2.046.873	490.329	2.537.202	0	0,1	14,95	613,8
5	12.288.375	2.537.202	2.046.873	490.329	2.537.202	0	0,1	14,95	613,8

C	P	PG	PL	P1	PX	
1	17,4%	83,7%	16,3%	17,4%	0,0%	2004 R./2004 Inc.
2	12,7%	91,0%	9,0%	12,7%	0,0%	1980 R./2004 Inc.
3	12,7%	91,0%	9,0%	12,7%	0,0%	1980 R./1980 Inc.
4	20,6%	80,7%	19,3%	20,6%	0,0%	1980 Ext. R/2004 Inc.
5	20,6%	80,7%	19,3%	20,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.770.665	586.683	48	586.635	586.683	0	0,1	14,95	613,8
2	2.066.594	96.355	15	96.34	96.355	0	0,1	14,80	818,2
3	2.066.594	96.355	15	96.34	96.355	0	0,1	14,80	818,2
4	4.704.071	490.328	33	490.295	490.328	0	0,1	14,95	613,8
5	4.704.071	490.328	33	490.295	490.328	0	0,1	14,95	613,8

C	P	PG	PL	P1	PX	
1	8,7%	0,0%	100,0%	8,7%	0,0%	2004 R./2004 Inc.
2	4,7%	0,0%	100,0%	4,7%	0,0%	1980 R./2004 Inc.
3	4,7%	0,0%	100,0%	4,7%	0,0%	1980 R./1980 Inc.
4	10,4%	0,0%	100,0%	10,4%	0,0%	1980 Ext. R/2004 Inc.
5	10,4%	0,0%	100,0%	10,4%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.954.040	3.018.450	3.018.397	53	3.018.450	0	0,1	15,05	613,7
2	6.369.736	971.576	971.557	19	971.576	0	0,1	15,20	818,0
3	6.369.736	971.576	971.557	19	971.576	0	0,1	15,20	818,0
4	7.584.304	2.046.874	2.046.840	34	2.046.874	0	0,1	15,05	613,7
5	7.584.304	2.046.874	2.046.840	34	2.046.874	0	0,1	15,05	613,7

C	P	PG	PL	P1	PX	
1	21,6%	100,0%	0,0%	21,6%	0,0%	2004 R./2004 Inc.
2	15,3%	100,0%	0,0%	15,3%	0,0%	1980 R./2004 Inc.
3	15,3%	100,0%	0,0%	15,3%	0,0%	1980 R./1980 Inc.
4	27,0%	100,0%	0,0%	27,0%	0,0%	1980 Ext. R/2004 Inc.
5	27,0%	100,0%	0,0%	27,0%	0,0%	1980 Ext./1980 Inc.



## 1.8. Table 53B – products, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 611,2 kg/m<sup>3</sup> to 1.163,9 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 15 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

Results ASTM D1250-80 standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.505.265	16.421.101	8.765.701	7.655.400	8.219.531	8.201.570	1,8	149,75	646,7
2	10.582.625	8.442.015	4.379.320	4.062.695	4.260.350	4.181.665	0,5	-15,30	800,3
3	2.116.525	166.851	144.851	22	158.305	8.546	0,2	-8,00	793,0
4	9.922.640	7.979.086	4.386.381	3.592.705	3.959.181	4.019.905	1,8	149,75	646,7
5	1.983.467	328.594	294.088	34.506	240.893	87.701	1,7	149,95	646,5

C	P	PG	PL	P1	PX	
1	80,1%	53,4%	46,6%	40,1%	40,0%	2004 R./2004 Inc.
2	79,8%	51,9%	48,1%	40,3%	39,5%	1980 R./2004 Inc.
3	7,9%	86,8%	13,2%	7,5%	0,4%	1980 R./1980 Inc.
4	80,4%	55,0%	45,0%	39,9%	40,5%	1980 Ext. R/2004 Inc.
5	16,6%	89,5%	10,5%	12,1%	4,4%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.771.696	5.439.650	2.664.036	2.775.614	2.663.685	2.775.965	0,8	-44,05	822,8
2	2.788.500	2.236.885	1.099.423	1.137.462	1.103.097	1.133.788	0,5	-15,30	800,3
3	557.7	22.083	109	21.974	21.114	969	0,2	-8,00	793,0
4	3.983.196	3.202.765	1.564.613	1.638.152	1.560.588	1.642.177	0,8	-44,05	822,8
5	796.119	35.794	1.308	34.486	23.323	12.471	0,5	-49,75	831,5

C	P	PG	PL	P1	PX	
1	80,3%	49,0%	51,0%	39,3%	41,0%	2004 R./2004 Inc.
2	80,2%	49,1%	50,9%	39,6%	40,7%	1980 R./2004 Inc.
3	4,0%	0,5%	99,5%	3,8%	0,2%	1980 R./1980 Inc.
4	80,4%	48,9%	51,1%	39,2%	41,2%	1980 Ext. R/2004 Inc.
5	4,5%	3,7%	96,3%	2,9%	1,6%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.733.569	10.981.451	6.101.665	4.879.786	5.555.846	5.425.605	1,8	149,75	646,7
2	7.794.125	6.205.130	3.279.897	2.925.233	3.157.253	3.047.877	0,3	15,20	792,7
3	1.558.825	144.768	144.742	26	137.191	7.577	0,2	48,80	740,5
4	5.939.444	4.776.321	2.821.768	1.954.553	2.398.593	2.377.728	1,8	149,75	646,7
5	1.187.348	292.8	292.78	20	217.57	75.23	1,7	149,95	646,5

C	P	PG	PL	P1	PX	
1	80,0%	55,6%	44,4%	40,5%	39,5%	2004 R./2004 Inc.
2	79,6%	52,9%	47,1%	40,5%	39,1%	1980 R./2004 Inc.
3	9,3%	100,0%	0,0%	8,8%	0,5%	1980 R./1980 Inc.
4	80,4%	59,1%	40,9%	40,4%	40,0%	1980 Ext. R/2004 Inc.
5	24,7%	100,0%	0,0%	18,3%	6,3%	1980 Ext./1980 Inc.

Results ASTM D1250-80 with "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.505.265	2.477.167	2.194.605	282.562	1.995.961	481.206	1,7	149,95	646,2
2	10.573.985	834.292	723.949	110.343	791.552	42.74	0,2	-7,60	793,4
3	10.573.985	834.292	723.949	110.343	791.552	42.74	0,2	-7,60	793,4
4	9.931.280	1.642.875	1.470.656	172.219	1.204.409	438.466	1,7	149,95	646,2
5	9.931.280	1.642.875	1.470.656	172.219	1.204.409	438.466	1,7	149,95	646,2

C	P	PG	PL	P1	PX	
1	12,1%	88,6%	11,4%	9,7%	2,3%	2004 R./2004 Inc.
2	7,9%	86,8%	13,2%	7,5%	0,4%	1980 R./2004 Inc.
3	7,9%	86,8%	13,2%	7,5%	0,4%	1980 R./1980 Inc.
4	16,5%	89,5%	10,5%	12,1%	4,4%	1980 Ext. R/2004 Inc.
5	16,5%	89,5%	10,5%	12,1%	4,4%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.771.696	289.64	7.309	282.331	222.219	67.421	0,5	-49,20	830,6
2	2.785.860	110.733	518	110.215	105.666	5.067	0,2	-7,60	793,4
3	2.785.860	110.733	518	110.215	105.666	5.067	0,2	-7,60	793,4
4	3.985.836	178.907	6.791	172.116	116.553	62.354	0,5	-49,20	830,6
5	3.985.836	178.907	6.791	172.116	116.553	62.354	0,5	-49,20	830,6

C	P	PG	PL	P1	PX	
1	4,3%	2,5%	97,5%	3,3%	1,0%	2004 R./2004 Inc.
2	4,0%	0,5%	99,5%	3,8%	0,2%	1980 R./2004 Inc.
3	4,0%	0,5%	99,5%	3,8%	0,2%	1980 R./1980 Inc.
4	4,5%	3,8%	96,2%	2,9%	1,6%	1980 Ext. R/2004 Inc.
5	4,5%	3,8%	96,2%	2,9%	1,6%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.733.569	2.187.527	2.187.296	231	1.773.742	413.785	1,7	149,95	646,2
2	7.788.125	723.559	723.431	128	685.886	37.673	0,2	47,65	742,3
3	7.788.125	723.559	723.431	128	685.886	37.673	0,2	47,65	742,3
4	5.945.444	1.463.968	1.463.865	103	1.087.856	376.112	1,7	149,95	646,2
5	5.945.444	1.463.968	1.463.865	103	1.087.856	376.112	1,7	0,00	0,0

C	P	PG	PL	P1	PX	
1	15,9%	100,0%	0,0%	12,9%	3,0%	2004 R./2004 Inc.
2	9,3%	100,0%	0,0%	8,8%	0,5%	1980 R./2004 Inc.
3	9,3%	100,0%	0,0%	8,8%	0,5%	1980 R./1980 Inc.
4	24,6%	100,0%	0,0%	18,3%	6,3%	1980 Ext. R/2004 Inc.
5	24,6%	100,0%	0,0%	18,3%	6,3%	1980 Ext./1980 Inc.

## 1.9. Table 53D – lubricants, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 801,3 kg/m<sup>3</sup> to 1.163,9 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 15 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

Results ASTM D1250-80 standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.086.915	10.469.020	5.306.447	5.162.573	5.237.091	5.231.929	0,3	17,15	833,2
2	11.096.428	8.876.484	4.507.483	4.369.001	4.440.542	4.435.942	0,3	17,15	833,2
3	2.219.046	74.172	72.385	1.787	74.172	0	0,1	17,15	833,0
4	1.990.487	1.592.536	798.964	793.572	796.549	795.987	0,3	-20,05	1.003,2
5	397.813	6.265	4.641	1.624	6.265	0	0,1	-20,05	1.003,0

C	P	PG	PL	P1	PX	
1	80,0%	50,7%	49,3%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	50,8%	49,2%	40,0%	40,0%	1980 R./2004 Inc.
3	3,3%	97,6%	2,4%	3,3%	0,0%	1980 R./1980 Inc.
4	80,0%	50,2%	49,8%	40,0%	40,0%	1980 Ext. R/2004 Inc.
5	1,6%	74,1%	25,9%	1,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.452.607	3.562.441	1.782.813	1.779.628	1.781.678	1.780.763	0,3	9,50	1.026,2
2	2.462.339	1.970.124	983.849	986.275	985.129	984.995	0,3	9,50	1.026,2
3	492.186	2.456	760	1.696	2.456	0	0,1	9,50	1.026,0
4	1.990.268	1.592.317	798.964	793.353	796.549	795.768	0,3	-20,05	1.003,2
5	397.813	6.265	4.641	1.624	6.265	0	0,1	-20,05	1.003,0

C	P	PG	PL	P1	PX	
1	80,0%	50,0%	50,0%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	49,9%	50,1%	40,0%	40,0%	1980 R./2004 Inc.
3	0,5%	30,9%	69,1%	0,5%	0,0%	1980 R./1980 Inc.
4	80,0%	50,2%	49,8%	40,0%	40,0%	1980 Ext. R/2004 Inc.
5	1,6%	74,1%	25,9%	1,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	8.634.308	6.906.579	3.523.634	3.382.945	3.455.413	3.451.166	0,3	17,15	833,2
2	8.634.089	6.906.360	3.523.634	3.382.726	3.455.413	3.450.947	0,3	17,15	833,2
3	1.726.860	71.716	71.625	91	71.716	0	0,1	17,15	833,0
4	219	219	0	219	0	219	0,2	15,05	1163,8
5	0	0	0	0	0	0	0,0	0,00	0,0

C	P	PG	PL	P1	PX	
1	80,0%	51,0%	49,0%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	51,0%	49,0%	40,0%	40,0%	1980 R./2004 Inc.
3	4,2%	99,9%	0,1%	4,2%	0,0%	1980 R./1980 Inc.
4	100,0%	0,0%	100,0%	0,0%	100,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



Results ASTM D1250-80 "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.086.915	401.528	384.41	17.118	401.528	0	0,1	17,15	811,4
2	11.096.647	370.247	361.205	9.042	370.247	0	0,1	17,15	811,4
3	11.096.647	370.247	361.205	9.042	370.247	0	0,1	17,15	811,4
4	1.990.268	31.281	23.205	8.076	31.281	0	0,1	-20,05	1.001,6
5	1.990.268	31.281	23.205	8.076	31.281	0	0,1	-20,05	1.001,6

C	P	PG	PL	P1	PX	
1	3,1%	95,7%	4,3%	3,1%	0,0%	2004 R./2004 Inc.
2	3,3%	97,6%	2,4%	3,3%	0,0%	1980 R./2004 Inc.
3	3,3%	97,6%	2,4%	3,3%	0,0%	1980 R./1980 Inc.
4	1,6%	74,2%	25,8%	1,6%	0,0%	1980 Ext. R/2004 Inc.
5	1,6%	74,2%	25,8%	1,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.452.607	43.667	27.025	16.642	43.667	0	0,1	9,50	1.014,3
2	2.462.339	12.386	3.82	8.566	12.386	0	0,1	9,50	1.014,3
3	2.462.339	12.386	3.82	8.566	12.386	0	0,1	9,50	1.014,3
4	1.990.268	31.281	23.205	8.076	31.281	0	0,1	-20,05	1.001,6
5	1.990.268	31.281	23.205	8.076	31.281	0	0,1	-20,05	1.001,6

C	P	PG	PL	P1	PX	
1	1,0%	61,9%	38,1%	1,0%	0,0%	2004 R./2004 Inc.
2	0,5%	30,8%	69,2%	0,5%	0,0%	1980 R./2004 Inc.
3	0,5%	30,8%	69,2%	0,5%	0,0%	1980 R./1980 Inc.
4	1,6%	74,2%	25,8%	1,6%	0,0%	1980 Ext. R/2004 Inc.
5	1,6%	74,2%	25,8%	1,6%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	8.634.308	357.861	357.385	476	357.861	0	0,1	17,15	811,4
2	8.634.308	357.861	357.385	476	357.861	0	0,1	17,15	811,4
3	8.634.308	357.861	357.385	476	357.861	0	0,1	17,15	811,4
4	0	0	0	0	0	0	0,0	0,00	0,0
5	0	0	0	0	0	0	0,0	0,00	0,0

C	P	PG	PL	P1	PX	
1	4,1%	99,9%	0,1%	4,1%	0,0%	2004 R./2004 Inc.
2	4,1%	99,9%	0,1%	4,1%	0,0%	1980 R./2004 Inc.
3	4,1%	99,9%	0,1%	4,1%	0,0%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.

## 1.10. Table 59A – crude oil, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 606,1 kg/m<sup>3</sup> to 1.161,2 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 20 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

Results ASTM D1250-80 standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.824.804	16.575.250	8.797.146	7.778.104	8.501.842	8.073.408	0,3	19,95	609,3
2	8.436.340	6.714.695	3.531.511	3.183.184	3.443.890	3.270.805	0,3	19,80	817,3
3	1.687.268	203.832	176.997	26.835	203.832	0	0,1	19,80	817,5
4	12.388.464	9.860.555	5.265.635	4.594.920	5.057.952	4.802.603	0,3	19,95	609,3
5	2.476.655	524.196	397.518	126.678	524.196	0	0,1	19,95	609,5

C	P	PG	PL	P1	PX	
1	79,6%	53,1%	46,9%	40,8%	38,8%	2004 R./2004 Inc.
2	79,6%	52,6%	47,4%	40,8%	38,8%	1980 R./2004 Inc.
3	12,1%	86,8%	13,2%	12,1%	0,0%	1980 R./1980 Inc.
4	79,6%	53,4%	46,6%	40,8%	38,8%	1980 Ext. R/2004 Inc.
5	21,2%	75,8%	24,2%	21,2%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.289.450	5.875.396	2.806.967	3.068.429	2.828.792	3.046.604	0,3	19,95	609,3
2	2.384.180	1.914.159	933.666	980.493	939.938	974.221	0,3	19,80	817,3
3	476.836	26.83	5	26.825	26.83	0	0,1	19,80	817,5
4	4.905.270	3.961.237	1.873.301	2.087.936	1.888.854	2.072.383	0,3	19,95	609,3
5	981.056	126.68	8	126.672	126.68	0	0,1	19,95	609,5

C	P	PG	PL	P1	PX	
1	80,6%	47,8%	52,2%	38,8%	41,8%	2004 R./2004 Inc.
2	80,3%	48,8%	51,2%	39,4%	40,9%	1980 R./2004 Inc.
3	5,6%	0,0%	100,0%	5,6%	0,0%	1980 R./1980 Inc.
4	80,8%	47,3%	52,7%	38,5%	42,2%	1980 Ext. R/2004 Inc.
5	12,9%	0,0%	100,0%	12,9%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.535.354	10.699.854	5.990.179	4.709.675	5.673.050	5.026.804	0,3	20,05	609,2
2	6.052.160	4.800.536	2.597.845	2.202.691	2.503.952	2.296.584	0,3	20,20	815,2
3	1.210.432	177.002	176.992	10	177.002	0	0,1	20,20	815,0
4	7.483.194	5.899.318	3.392.334	2.506.984	3.169.098	2.730.220	0,3	20,05	609,2
5	1.495.599	397.516	397.51	6	397.516	0	0,1	20,05	609,0

C	P	PG	PL	P1	PX	
1	79,1%	56,0%	44,0%	41,9%	37,1%	2004 R./2004 Inc.
2	79,3%	54,1%	45,9%	41,4%	37,9%	1980 R./2004 Inc.
3	14,6%	100,0%	0,0%	14,6%	0,0%	1980 R./1980 Inc.
4	78,8%	57,5%	42,5%	42,3%	36,5%	1980 Ext. R/2004 Inc.
5	26,6%	100,0%	0,0%	26,6%	0,0%	1980 Ext./1980 Inc.

Results ASTM D1250-80 with "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.824.804	3.640.484	2.872.698	767.786	3.640.484	0	0,1	19,95	609,1
2	8.436.316	1.017.599	883.616	133.983	1.017.599	0	0,1	19,80	815,2
3	8.436.316	1.017.599	883.616	133.983	1.017.599	0	0,1	19,80	815,2
4	12.388.488	2.622.885	1.989.082	633.803	2.622.885	0	0,1	19,95	609,1
5	12.388.488	2.622.885	1.989.082	633.803	2.622.885	0	0,1	19,95	609,1

C	P	PG	PL	P1	PX	
1	17,5%	78,9%	21,1%	17,5%	0,0%	2004 R./2004 Inc.
2	12,1%	86,8%	13,2%	12,1%	0,0%	1980 R./2004 Inc.
3	12,1%	86,8%	13,2%	12,1%	0,0%	1980 R./1980 Inc.
4	21,2%	75,8%	24,2%	21,2%	0,0%	1980 Ext. R/2004 Inc.
5	21,2%	75,8%	24,2%	21,2%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.289.450	767.791	59	767.732	767.791	0	0,1	19,95	609,1
2	2.384.189	133.983	31	133.952	133.983	0	0,1	19,80	815,2
3	2.384.189	133.983	31	133.952	133.983	0	0,1	19,80	815,2
4	4.905.261	633.808	28	633.78	633.808	0	0,1	19,95	609,1
5	4.905.261	633.808	28	633.78	633.808	0	0,1	19,95	609,1

C	P	PG	PL	P1	PX	
1	10,5%	0,0%	100,0%	10,5%	0,0%	2004 R./2004 Inc.
2	5,6%	0,0%	100,0%	5,6%	0,0%	1980 R./2004 Inc.
3	5,6%	0,0%	100,0%	5,6%	0,0%	1980 R./1980 Inc.
4	12,9%	0,0%	100,0%	12,9%	0,0%	1980 Ext. R/2004 Inc.
5	12,9%	0,0%	100,0%	12,9%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.535.354	2.872.693	2.872.639	54	2.872.693	0	0,1	20,05	609,0
2	6.052.127	883.616	883.585	31	883.616	0	0,1	20,20	814,9
3	6.052.127	883.616	883.585	31	883.616	0	0,1	20,20	814,9
4	7.483.227	1.989.077	1.989.054	23	1.989.077	0	0,1	20,05	609,0
5	7.483.227	1.989.077	1.989.054	23	1.989.077	0	0,1	20,05	609,0

C	P	PG	PL	P1	PX	
1	21,2%	100,0%	0,0%	21,2%	0,0%	2004 R./2004 Inc.
2	14,6%	100,0%	0,0%	14,6%	0,0%	1980 R./2004 Inc.
3	14,6%	100,0%	0,0%	14,6%	0,0%	1980 R./1980 Inc.
4	26,6%	100,0%	0,0%	26,6%	0,0%	1980 Ext. R/2004 Inc.
5	26,6%	100,0%	0,0%	26,6%	0,0%	1980 Ext./1980 Inc.

## 1.11. Table 59B – products, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 606,1 kg/m<sup>3</sup> to 1.160,6 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 20 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$

Results ASTM D1250-80 standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.595.894	16.487.819	8.733.555	7.754.264	8.239.166	8.248.653	1,0	-50,00	827,8
2	10.582.645	8.444.798	4.354.838	4.089.960	4.253.529	4.191.269	0,5	-10,55	795,3
3	2.116.529	167.176	135.282	31.894	159.724	7.452	0,2	-2,40	786,5
4	10.013.249	8.043.021	4.378.717	3.664.304	3.985.637	4.057.384	1,0	-50,00	827,8
5	2.001.888	329.774	280.837	48.937	247.701	82.073	0,8	149,65	670,5

C	P	PG	PL	P1	PX	
1	80,1%	53,0%	47,0%	40,0%	40,0%	2004 R./2004 Inc.
2	79,8%	51,6%	48,4%	40,2%	39,6%	1980 R./2004 Inc.
3	7,9%	80,9%	19,1%	7,5%	0,4%	1980 R./1980 Inc.
4	80,3%	54,4%	45,6%	39,8%	40,5%	1980 Ext. R/2004 Inc.
5	16,5%	85,2%	14,8%	12,4%	4,1%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.280.783	5.851.143	2.845.207	3.005.936	2.854.875	2.996.268	1,0	-50,00	827,8
2	3.211.000	2.576.953	1.259.701	1.317.252	1.267.683	1.309.270	0,5	-10,55	795,3
3	642,2	31.903	29	31.874	28.926	2.977	0,2	-2,40	786,5
4	4.069.783	3.274.190	1.585.506	1.688.684	1.587.192	1.686.998	1,0	-50,00	827,8
5	814.236	48.086	578	47.508	34.375	13.711	0,6	-50,00	828,0

C	P	PG	PL	P1	PX	
1	80,4%	48,6%	51,4%	39,2%	41,2%	2004 R./2004 Inc.
2	80,3%	48,9%	51,1%	39,5%	40,8%	1980 R./2004 Inc.
3	5,0%	0,1%	99,9%	4,5%	0,5%	1980 R./1980 Inc.
4	80,5%	48,4%	51,6%	39,0%	41,5%	1980 Ext. R/2004 Inc.
5	5,9%	1,2%	98,8%	4,2%	1,7%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.315.111	10.636.676	5.888.348	4.748.328	5.384.291	5.252.385	0,9	149,65	670,7
2	7.371.645	5.867.845	3.095.137	2.772.708	2.985.846	2.881.999	0,3	20,30	773,7
3	1.474.329	135.273	135.253	20	130.798	4.475	0,2	50,10	740,0
4	5.943.466	4.768.831	2.793.211	1.975.620	2.398.445	2.370.386	0,9	149,65	670,7
5	1.187.652	281.688	280.259	1.429	213.326	68.362	0,8	149,65	670,5

C	P	PG	PL	P1	PX	
1	79,9%	55,4%	44,6%	40,4%	39,4%	2004 R./2004 Inc.
2	79,6%	52,7%	47,3%	40,5%	39,1%	1980 R./2004 Inc.
3	9,2%	100,0%	0,0%	8,9%	0,3%	1980 R./1980 Inc.
4	80,2%	58,6%	41,4%	40,4%	39,9%	1980 Ext. R/2004 Inc.
5	23,7%	99,5%	0,5%	18,0%	5,8%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	20.595.894	2.485.134	2.081.871	403.263	2.037.704	447.43	0,8	149,40	670,7
2	10.574.012	836.274	676.659	159.615	799.239	37.035	0,2	-2,00	785,9
3	10.574.012	836.274	676.659	159.615	799.239	37.035	0,2	-2,00	785,9
4	10.021.882	1.648.860	1.405.212	243.648	1.238.465	410.395	0,8	149,40	670,7
5	10.021.882	1.648.860	1.405.212	243.648	1.238.465	410.395	0,8	149,40	670,7

C	P	PG	PL	P1	PX	
1	12,1%	83,8%	16,2%	9,9%	2,2%	2004 R./2004 Inc.
2	7,9%	80,9%	19,1%	7,6%	0,4%	1980 R./2004 Inc.
3	7,9%	80,9%	19,1%	7,6%	0,4%	1980 R./1980 Inc.
4	16,5%	85,2%	14,8%	12,4%	4,1%	1980 Ext. R/2004 Inc.
5	16,5%	85,2%	14,8%	12,4%	4,1%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.280.783	398.902	2.909	395.993	315.659	83.243	0,6	-49,40	826,7
2	3.207.960	159.659	126	159.533	144.934	14.725	0,2	-2,00	785,9
3	3.207.960	159.659	126	159.533	144.934	14.725	0,2	-2,00	785,9
4	4.072.823	239.243	2.783	236.46	170.725	68.518	0,6	-49,40	826,7
5	4.072.823	239.243	2.783	236.46	170.725	68.518	0,6	-49,40	826,7

C	P	PG	PL	P1	PX	
1	5,5%	0,7%	99,3%	4,3%	1,1%	2004 R./2004 Inc.
2	5,0%	0,1%	99,9%	4,5%	0,5%	1980 R./2004 Inc.
3	5,0%	0,1%	99,9%	4,5%	0,5%	1980 R./1980 Inc.
4	5,9%	1,2%	98,8%	4,2%	1,7%	1980 Ext. R/2004 Inc.
5	5,9%	1,2%	98,8%	4,2%	1,7%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.315.111	2.086.232	2.078.962	1.722.045	364.187	0,8	149,40	670,7	1.722.045
2	7.366.052	676.615	676.533	654.305	22.31	0,2	50,10	740,0	654.305
3	7.366.052	676.615	676.533	654.305	22.31	0,2	50,10	740,0	654.305
4	5.949.059	1.409.617	1.402.429	1.067.740	341.877	0,8	149,40	670,7	1.067.740
5	5.949.059	1.409.617	1.402.429	1.067.740	341.877	0,8	149,65	670,5	1.067.740

C	P	PG	PL	P1	PX	
1	15,7%	99,7%	0,3%	12,9%	2,7%	2004 R./2004 Inc.
2	9,2%	100,0%	0,0%	8,9%	0,3%	1980 R./2004 Inc.
3	9,2%	100,0%	0,0%	8,9%	0,3%	1980 R./1980 Inc.
4	23,7%	99,5%	0,5%	17,9%	5,7%	1980 Ext. R/2004 Inc.
5	23,7%	99,5%	0,5%	17,9%	5,7%	1980 Ext./1980 Inc.

## 1.12. Table 59D – lubricants, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Observed density:** 798,1 kg/m<sup>3</sup> to 1.160,7 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Base density / kg/m<sup>3</sup> @ 20 °C

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 with standard rounding:

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.128.559	10.502.816	5.321.390	5.181.426	5.253.901	5.248.915	0,3	21,35	806,3
2	11.157.282	8.925.925	4.533.435	4.392.490	4.465.174	4.460.751	0,3	21,35	806,3
3	2.230.456	74.91	71.672	3.238	74.91	0	0,1	21,35	806,5
4	1.971.277	1.576.891	787.955	788.936	788.727	788.164	0,3	-20,15	980,2
5	394.213	6.005	2.621	3.384	6.005	0	0,1	-20,15	980,0

C	P	PG	PL	P1	PX	
1	80,0%	50,7%	49,3%	40,0%	40,0%	2004 R./2004 Inc.
2	80,0%	50,8%	49,2%	40,0%	40,0%	1980 R./2004 Inc.
3	3,4%	95,7%	4,3%	3,4%	0,0%	1980 R./1980 Inc.
4	80,0%	50,0%	50,0%	40,0%	40,0%	1980 Ext. R/2004 Inc.
5	1,5%	43,6%	56,4%	1,5%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.772.064	3.817.447	1.906.619	1.910.828	1.909.165	1.908.282	0,3	14,35	839,8
2	2.800.996	2.240.765	1.118.664	1.122.101	1.120.438	1.120.327	0,3	14,35	839,8
3	560.198	3.784	793	2.991	3.784	0	0,1	14,35	840,0
4	1.971.068	1.576.682	787.955	788.727	788.727	787.955	0,3	-20,15	980,2
5	394.213	6.005	2.621	3.384	6.005	0	0,1	-20,15	980,0

C	P	PG	PL	P1	PX	
1	10,5%	0,0%	100,0%	10,5%	0,0%	2004 R./2004 Inc.
2	5,6%	0,0%	100,0%	5,6%	0,0%	1980 R./2004 Inc.
3	5,6%	0,0%	100,0%	5,6%	0,0%	1980 R./1980 Inc.
4	12,9%	0,0%	100,0%	12,9%	0,0%	1980 Ext. R/2004 Inc.
5	12,9%	0,0%	100,0%	12,9%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.535.354	2.872.693	2.872.639	54	2.872.693	0	0,1	20,05	609,0
2	6.052.127	883.616	883.585	31	883.616	0	0,1	20,20	814,9
3	6.052.127	883.616	883.585	31	883.616	0	0,1	20,20	814,9
4	7.483.227	1.989.077	1.989.054	23	1.989.077	0	0,1	20,05	609,0
5	7.483.227	1.989.077	1.989.054	23	1.989.077	0	0,1	20,05	609,0

C	P	PG	PL	P1	PX	
1	21,2%	100,0%	0,0%	21,2%	0,0%	2004 R./2004 Inc.
2	14,6%	100,0%	0,0%	14,6%	0,0%	1980 R./2004 Inc.
3	14,6%	100,0%	0,0%	14,6%	0,0%	1980 R./1980 Inc.
4	26,6%	100,0%	0,0%	26,6%	0,0%	1980 Ext. R/2004 Inc.
5	26,6%	100,0%	0,0%	26,6%	0,0%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data):

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.128.559	404.979	371.946	33.033	404.979	0	0,1	21,35	798,1
2	11.157.491	374.956	358.716	16.24	374.956	0	0,1	21,35	798,1
3	11.157.491	374.956	358.716	16.24	374.956	0	0,1	21,35	798,1
4	1.971.068	30.023	13.23	16.793	30.023	0	0,1	-20,15	976,8
5	1.971.068	30.023	13.23	16.793	30.023	0	0,1	-20,15	976,8

C	P	PG	PL	P1	PX	
1	3,1%	91,8%	8,2%	3,1%	0,0%	2004 R./2004 Inc.
2	3,4%	95,7%	4,3%	3,4%	0,0%	1980 R./2004 Inc.
3	3,4%	95,7%	4,3%	3,4%	0,0%	1980 R./1980 Inc.
4	1,5%	44,1%	55,9%	1,5%	0,0%	1980 Ext. R/2004 Inc.
5	1,5%	44,1%	55,9%	1,5%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.772.064	48.96	17.255	31.705	48.96	0	0,1	14,35	823,6
2	2.800.996	18.937	4.025	14.912	18.937	0	0,1	14,35	823,6
3	2.800.996	18.937	4.025	14.912	18.937	0	0,1	14,35	823,6
4	1.971.068	30.023	13.23	16.793	30.023	0	0,1	-20,15	976,8
5	1.971.068	30.023	13.23	16.793	30.023	0	0,1	-20,15	976,8

C	P	PG	PL	P1	PX	
1	1,0%	35,2%	64,8%	1,0%	0,0%	2004 R./2004 Inc.
2	0,7%	21,3%	78,7%	0,7%	0,0%	1980 R./2004 Inc.
3	0,7%	21,3%	78,7%	0,7%	0,0%	1980 R./1980 Inc.
4	1,5%	44,1%	55,9%	1,5%	0,0%	1980 Ext. R/2004 Inc.
5	1,5%	44,1%	55,9%	1,5%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	8.356.495	356.019	354.691	356.019	0	0,1	21,35	798,1	356.019
2	8.356.495	356.019	354.691	356.019	0	0,1	21,35	798,1	356.019
3	8.356.495	356.019	354.691	356.019	0	0,1	21,35	798,1	356.019
4	0	0	0	0	0	0,0	0,00	0,0	0
5	0	0	0	0	0	0,0	0,00	0,0	0

C	P	PG	PL	P1	PX	
1	4,3%	99,6%	0,4%	4,3%	0,0%	2004 R./2004 Inc.
2	4,3%	99,6%	0,4%	4,3%	0,0%	1980 R./2004 Inc.
3	4,3%	99,6%	0,4%	4,3%	0,0%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



## 1.13. Table 6A – crude oil, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base density @ 60 °F:** -10 °API to 100 °API, increment 0,1 °API

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P:** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.963.600	3.334.064	672.336	2.661.728	1.145.810	2.188.254	0,00007	-7,1	99,5
2	1.278.051	959.053	158.655	800.398	525.676	433.377	0,00006	32,6	54,8
3	1.278.051	959.053	158.655	800.398	525.676	433.377	0,00006	32,6	54,8
4	2.685.549	2.375.011	513.681	1.861.330	620.134	1.754.877	0,00007	-7,1	99,5
5	2.685.549	2.375.011	513.681	1.861.330	620.134	1.754.877	0,00007	-7,1	99,5

C	P	PG	PL	P1	PX	
1	84,1%	20,2%	79,8%	28,9%	55,2%	2004 R./2004 Inc.
2	75,0%	16,5%	83,5%	41,1%	33,9%	1980 R./2004 Inc.
3	75,0%	16,5%	83,5%	41,1%	33,9%	1980 R./1980 Inc.
4	88,4%	21,6%	78,4%	23,1%	65,3%	1980 Ext. R/2004 Inc.
5	88,4%	21,6%	78,4%	23,1%	65,3%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.299.180	1.169.148	672.336	496.812	259.438	909.71	0,00007	-7,1	99,5
2	330,6	297.457	158.655	138.802	65.959	231.498	0,00006	32,6	54,8
3	330,6	297.457	158.655	138.802	65.959	231.498	0,00006	32,6	54,8
4	968,58	871.691	513.681	358,01	193.479	678.212	0,00007	-7,1	99,5
5	968,58	871.691	513.681	358,01	193.479	678.212	0,00007	-7,1	99,5

C	P	PG	PL	P1	PX	
1	90,0%	57,5%	42,5%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	53,3%	46,7%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	53,3%	46,7%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	58,9%	41,1%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	58,9%	41,1%	20,0%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.664.420	2.164.916	0	2.164.916	886.372	1.278.544	0,00007	280,8	96,9
2	947.451	661.596	0	661.596	459.717	201.879	0,00004	228,9	38,8
3	947.451	661.596	0	661.596	459.717	201.879	0,00004	228,9	38,8
4	1.716.969	1.503.320	0	1.503.320	426.655	1.076.665	0,00007	280,8	96,9
5	1.716.969	1.503.320	0	1.503.320	426.655	1.076.665	0,00007	280,8	96,9

C	P	PG	PL	P1	PX	
1	81,3%	0,0%	100,0%	33,3%	48,0%	2004 R./2004 Inc.
2	69,8%	0,0%	100,0%	48,5%	21,3%	1980 R./2004 Inc.
3	69,8%	0,0%	100,0%	48,5%	21,3%	1980 R./1980 Inc.
4	87,6%	0,0%	100,0%	24,8%	62,7%	1980 Ext. R/2004 Inc.
5	87,6%	0,0%	100,0%	24,8%	62,7%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.963.600	506.475	87.913	418.562	506.475	0	0,0001	59,8	78,1
2	1.278.051	84.445	9.876	74.569	84.445	0	0,0001	59,2	3,8
3	1.278.051	84.445	9.876	74.569	84.445	0	0,0001	59,2	3,8
4	2.685.549	422.03	78.037	343.993	422.03	0	0,0001	59,8	78,1
5	2.685.549	422.03	78.037	343.993	422.03	0	0,0001	59,8	78,1

C	P	PG	PL	P1	PX	
1	12,8%	17,4%	82,6%	12,8%	0,0%	2004 R./2004 Inc.
2	6,6%	11,7%	88,3%	6,6%	0,0%	1980 R./2004 Inc.
3	6,6%	11,7%	88,3%	6,6%	0,0%	1980 R./1980 Inc.
4	15,7%	18,5%	81,5%	15,7%	0,0%	1980 Ext. R/2004 Inc.
5	15,7%	18,5%	81,5%	15,7%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.299.180	87.913	87.913	87.913	0	0,0001	59,8	78,1	87.913
2	330.6	9.876	9.876	9.876	0	0,0001	59,2	3,8	9.876
3	330.6	9.876	9.876	9.876	0	0,0001	59,2	3,8	9.876
4	968.58	78.037	78.037	78.037	0	0,0001	59,8	78,1	78.037
5	968.58	78.037	78.037	78.037	0	0,0001	59,8	78,1	78.037

C	P	PG	PL	P1	PX	
1	6,8%	100,0%	0,0%	6,8%	0,0%	2004 R./2004 Inc.
2	3,0%	100,0%	0,0%	3,0%	0,0%	1980 R./2004 Inc.
3	3,0%	100,0%	0,0%	3,0%	0,0%	1980 R./1980 Inc.
4	8,1%	100,0%	0,0%	8,1%	0,0%	1980 Ext. R/2004 Inc.
5	8,1%	100,0%	0,0%	8,1%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.664.420	418.562	0	418.562	418.562	0	0,0001	79,3	98,7
2	947.451	74.569	0	74.569	74.569	0	0,0001	88,9	54,5
3	947.451	74.569	0	74.569	74.569	0	0,0001	88,9	54,5
4	1.716.969	343.993	0	343.993	343.993	0	0,0001	79,3	98,7
5	1.716.969	343.993	0	343.993	343.993	0	0,0001	79,3	98,7

C	P	PG	PL	P1	PX	
1	15,7%	0,0%	100,0%	15,7%	0,0%	2004 R./2004 Inc.
2	7,9%	0,0%	100,0%	7,9%	0,0%	1980 R./2004 Inc.
3	7,9%	0,0%	100,0%	7,9%	0,0%	1980 R./1980 Inc.
4	20,0%	0,0%	100,0%	20,0%	0,0%	1980 Ext. R/2004 Inc.
5	20,0%	0,0%	100,0%	20,0%	0,0%	1980 Ext./1980 Inc.



## 1.14. Table 6B – products, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base density @ 60 °F:** -10 °API to 100 °API, increment 0,1 °API

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P:** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF -5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.963.600	3.387.286	677.763	2.709.523	1.111.483	2.275.803	0,00007	-4,9	91,4
2	1.728.351	1.335.704	249.394	1.086.310	700.666	635.038	0,00006	37,1	84,8
3	1.728.351	1.335.704	249.394	1.086.310	700.666	635.038	0,00006	37,1	84,8
4	2.235.249	2.051.582	428.369	1.623.213	410.817	1.640.765	0,00007	-4,9	91,4
5	2.235.249	2.051.582	428.369	1.623.213	410.817	1.640.765	0,00007	-4,9	91,4

C	P	PG	PL	P1	PX	
1	85,5%	20,0%	80,0%	28,0%	57,4%	2004 R./2004 Inc.
2	77,3%	18,7%	81,3%	40,5%	36,7%	1980 R./2004 Inc.
3	77,3%	18,7%	81,3%	40,5%	36,7%	1980 R./1980 Inc.
4	91,8%	20,9%	79,1%	18,4%	73,4%	1980 Ext. R/2004 Inc.
5	91,8%	20,9%	79,1%	18,4%	73,4%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.299.180	1.169.029	677.763	491.266	259.266	909.763	0,00007	-4,9	91,4
2	510.6	459.484	249.394	210.09	101.762	357.722	0,00006	37,1	84,8
3	510.6	459.484	249.394	210.09	101.762	357.722	0,00006	37,1	84,8
4	788.58	709.545	428.369	281.176	157.504	552.041	0,00007	-4,9	91,4
5	788.58	709.545	428.369	281.176	157.504	552.041	0,00007	-4,9	91,4

C	P	PG	PL	P1	PX	
1	90,0%	58,0%	42,0%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	54,3%	45,7%	19,9%	70,1%	1980 R./2004 Inc.
3	90,0%	54,3%	45,7%	19,9%	70,1%	1980 R./1980 Inc.
4	90,0%	60,4%	39,6%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	60,4%	39,6%	20,0%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.664.420	2.218.257	0	2.218.257	852.217	1.366.040	0,00007	278,3	95,2
2	1.217.751	876.22	0	876.22	598.904	277.316	0,00004	236,7	37,6
3	1.217.751	876.22	0	876.22	598.904	277.316	0,00004	236,7	37,6
4	1.446.669	1.342.037	0	1.342.037	253.313	1.088.724	0,00007	278,3	95,2
5	1.446.669	1.342.037	0	1.342.037	253.313	1.088.724	0,00007	278,3	95,2

C	P	PG	PL	P1	PX	
	83,3%	0,0%	100,0%	32,0%	51,3%	2004 R./2004 Inc.
	72,0%	0,0%	100,0%	49,2%	22,8%	1980 R./2004 Inc.
	72,0%	0,0%	100,0%	49,2%	22,8%	1980 R./1980 Inc.
	92,8%	0,0%	100,0%	17,5%	75,3%	1980 Ext. R/2004 Inc.
	92,8%	0,0%	100,0%	17,5%	75,3%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	3.963.600	544.256	93.318	450.938	544.256	0	0,0001	59,6	93,4
2	1.728.351	121.121	19.546	101.575	121.121	0	0,0001	59,3	52,4
3	1.728.351	121.121	19.546	101.575	121.121	0	0,0001	59,3	52,4
4	2.235.249	423.135	73.772	349.363	423.135	0	0,0001	59,6	93,4
5	2.235.249	423.135	73.772	349.363	423.135	0	0,0001	59,6	93,4

C	P	PG	PL	P1	PX	
1	13,7%	17,1%	82,9%	13,7%	0,0%	2004 R./2004 Inc.
2	7,0%	16,1%	83,9%	7,0%	0,0%	1980 R./2004 Inc.
3	7,0%	16,1%	83,9%	7,0%	0,0%	1980 R./1980 Inc.
4	18,9%	17,4%	82,6%	18,9%	0,0%	1980 Ext. R/2004 Inc.
5	18,9%	17,4%	82,6%	18,9%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.299.180	93.318	93.318	0	93.318	0	0,0001	59,6	93,4
2	510,6	19.546	19.546	0	19.546	0	0,0001	59,3	52,4
3	510,6	19.546	19.546	0	19.546	0	0,0001	59,3	52,4
4	788,58	73.772	73.772	0	73.772	0	0,0001	59,6	93,4
5	788,58	73.772	73.772	0	73.772	0	0,0001	59,6	93,4

C	P	PG	PL	P1	PX	
1	7,2%	100,0%	0,0%	7,2%	0,0%	2004 R./2004 Inc.
2	3,8%	100,0%	0,0%	3,8%	0,0%	1980 R./2004 Inc.
3	3,8%	100,0%	0,0%	3,8%	0,0%	1980 R./1980 Inc.
4	9,4%	100,0%	0,0%	9,4%	0,0%	1980 Ext. R/2004 Inc.
5	9,4%	100,0%	0,0%	9,4%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	2.664.420	450.938	0	450.938	450.938	0	0,0001	79,4	91,6
2	1.217.751	101.575	0	101.575	101.575	0	0,0001	81,2	78,4
3	1.217.751	101.575	0	101.575	101.575	0	0,0001	81,2	78,4
4	1.446.669	349.363	0	349.363	349.363	0	0,0001	79,4	91,6
5	1.446.669	349.363	0	349.363	349.363	0	0,0001	79,4	91,6

C	P	PG	PL	P1	PX	
1	16,9%	0,0%	100,0%	16,9%	0,0%	2004 R./2004 Inc.
2	8,3%	0,0%	100,0%	8,3%	0,0%	1980 R./2004 Inc.
3	8,3%	0,0%	100,0%	8,3%	0,0%	1980 R./1980 Inc.
4	24,1%	0,0%	100,0%	24,1%	0,0%	1980 Ext. R/2004 Inc.
5	24,1%	0,0%	100,0%	24,1%	0,0%	1980 Ext./1980 Inc.

## 1.15. Table 6C – special applications, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Thermal expansion coefficient @ 60 °F:** 0,0002300 1 /°F to 0,0009300 1/ °F, increment 0,0000001

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**TTLCB:** Thermal expansion coefficient for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$

VCF - 5 decimals

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	25.203.600	20.210.183	6.121.479	14.088.704	6.055.477	14.154.706	0,00011	283,5	0,0009297
2	12.416.103	8.983.323	2.746.734	6.236.589	3.569.434	5.413.889	0,00007	23,8	0,0008892
3	2.483.821	1.948.325	391.504	1.556.821	1.012.810	935.515	0,00006	37,9	0,0009130
4	12.787.497	11.226.860	3.374.745	7.852.115	2.486.043	8.740.817	0,00011	283,5	0,0009297
5	2.559.779	2.413.878	479.221	1.934.657	339.225	2.074.653	0,00007	-12,6	0,0009140

C	P	PG	PL	P1	PX				
1	80,2%	30,3%	69,7%	24,0%	56,2%				2004 R./2004 Inc.
2	72,4%	30,6%	69,4%	28,7%	43,6%				1980 R./2004 Inc.
3	78,4%	20,1%	79,9%	40,8%	37,7%				1980 R./1980 Inc.
4	87,8%	30,1%	69,9%	19,4%	68,4%				1980 Ext. R/2004 Inc.
5	94,3%	19,9%	80,1%	13,3%	81,0%				1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	8.261.180	7.436.238	4.350.481	3.085.757	1.647.720	5.788.518	0,00009	-32,0	0,0009242
2	3.961.800	3.566.764	1.957.011	1.609.753	791.538	2.775.226	0,00007	23,8	0,0008892
3	792.6	713.542	391.504	322.038	158.088	555.454	0,00006	37,9	0,0009130
4	4.299.380	3.869.474	2.393.470	1.476.004	856.182	3.013.292	0,00009	-32,0	0,0009242
5	860.58	774.441	479.221	295.22	171.806	602.635	0,00007	-12,6	0,0009140

C	P	PG	PL	P1	PX				
1	90,0%	58,5%	41,5%	19,9%	70,1%				2004 R./2004 Inc.
2	90,0%	54,9%	45,1%	20,0%	70,0%				1980 R./2004 Inc.
3	90,0%	54,9%	45,1%	19,9%	70,1%				1980 R./1980 Inc.
4	90,0%	61,9%	38,1%	19,9%	70,1%				1980 Ext. R/2004 Inc.
5	90,0%	61,9%	38,1%	20,0%	70,0%				1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	16.942.420	12.773.945	1.770.998	11.002.947	4.407.757	8.366.188	0,00011	283,5	0,0009297
2	8.454.303	5.416.559	789.723	4.626.836	2.777.896	2.638.663	0,00007	235,1	0,0005097
3	1.691.221	1.234.783	0	1.234.783	854.722	380.061	0,00003	136,6	0,0009275
4	8.488.117	7.357.386	981.275	6.376.111	1.629.861	5.727.525	0,00011	283,5	0,0009297
5	1.699.199	1.639.437	0	1.639.437	167.419	1.472.018	0,00006	263,5	0,0009280

C	P	PG	PL	P1	PX				
1	75,4%	13,9%	86,1%	26,0%	49,4%				2004 R./2004 Inc.
2	64,1%	14,6%	85,4%	32,9%	31,2%				1980 R./2004 Inc.
3	73,0%	0,0%	100,0%	50,5%	22,5%				1980 R./1980 Inc.
4	86,7%	13,3%	86,7%	19,2%	67,5%				1980 Ext. R/2004 Inc.
5	96,5%	0,0%	100,0%	9,9%	86,6%				1980 Ext./1980 Inc.

VCF - 4 decimals

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	25.203.600	4.312.975	903.77	3.409.205	4.312.428	547	0,0002	284,6	0,0009247
2	12.416.103	1.115.449	262.639	852.81	1.115.449	0	0,0001	59,9	0,0004998
3	2.483.821	175.994	35.039	140.955	175.994	0	0,0001	59,8	0,0007500
4	12.787.497	3.197.526	641.131	2.556.395	3.196.979	547	0,0002	284,6	0,0009247
5	2.559.779	564.513	92.032	472.481	564.513	0	0,0001	59,4	0,0002500

C	P	PG	PL	P1	PX	
1	17,1%	21,0%	79,0%	17,1%	0,0%	2004 R./2004 Inc.
2	9,0%	23,5%	76,5%	9,0%	0,0%	1980 R./2004 Inc.
3	7,1%	19,9%	80,1%	7,1%	0,0%	1980 R./1980 Inc.
4	25,0%	20,1%	79,9%	25,0%	0,0%	1980 Ext. R/2004 Inc.
5	22,1%	16,3%	83,7%	22,1%	0,0%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	8.261.180	774.494	703.931	70.563	774.494	0	0,0001	59,9	0,0004998
2	3.961.800	202.082	188.415	13.667	202.082	0	0,0001	59,9	0,0004998
3	792.6	35.039	35.039	0	35.039	0	0,0001	59,8	0,0007500
4	4.299.380	572.412	515.516	56.896	572.412	0	0,0001	59,8	0,0002498
5	860.58	92.032	92.032	0	92.032	0	0,0001	59,4	0,0002500

C	P	PG	PL	P1	PX	
1	9,4%	90,9%	9,1%	9,4%	0,0%	2004 R./2004 Inc.
2	5,1%	93,2%	6,8%	5,1%	0,0%	1980 R./2004 Inc.
3	4,4%	100,0%	0,0%	4,4%	0,0%	1980 R./1980 Inc.
4	13,3%	90,1%	9,9%	13,3%	0,0%	1980 Ext. R/2004 Inc.
5	10,7%	100,0%	0,0%	10,7%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	16.942.420	3.538.481	199.839	3.338.642	3.537.934	547	0,0002	284,6	0,0009247
2	8.454.303	913.367	74.224	839.143	913.367	0	0,0001	71,7	0,0008987
3	1.691.221	140.955	0	140.955	140.955	0	0,0001	80,9	0,0009160
4	8.488.117	2.625.114	125.615	2.499.499	2.624.567	547	0,0002	284,6	0,0009247
5	1.699.199	472.481	0	472.481	472.481	0	0,0001	134,3	0,0002550

C	P	PG	PL	P1	PX	
1	20,9%	5,6%	94,4%	20,9%	0,0%	2004 R./2004 Inc.
2	10,8%	8,1%	91,9%	10,8%	0,0%	1980 R./2004 Inc.
3	8,3%	0,0%	100,0%	8,3%	0,0%	1980 R./1980 Inc.
4	30,9%	4,8%	95,2%	30,9%	0,0%	1980 Ext. R/2004 Inc.
5	27,8%	0,0%	100,0%	27,8%	0,0%	1980 Ext./1980 Inc.



## 1.16. Table 6D – lubricants, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base density @ 60 °F:** -10 °API to 45 °API, increment 0,1 °API

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P:** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.980.000	1.593.517	323.187	1.270.330	720.163	873.354	0,00006	23,5	35,3
2	1.650.550	1.295.864	157.239	1.138.625	653.576	642.288	0,00006	23,5	35,3
3	1.650.550	1.295.864	157.239	1.138.625	653.576	642.288	0,00006	23,5	35,3
4	329.45	297.653	165.948	131.705	66.587	231.066	0,00006	-0,1	-4,3
5	329.45	297.653	165.948	131.705	66.587	231.066	0,00006	-0,1	-4,3

C	P	PG	PL	P1	PX	
1	80,5%	20,3%	79,7%	36,4%	44,1%	2004 R./2004 Inc.
2	78,5%	12,1%	87,9%	39,6%	38,9%	1980 R./2004 Inc.
3	78,5%	12,1%	87,9%	39,6%	38,9%	1980 R./1980 Inc.
4	90,3%	55,8%	44,2%	20,2%	70,1%	1980 Ext. R/2004 Inc.
5	90,3%	55,8%	44,2%	20,2%	70,1%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	649	584.329	323.187	261.142	129.914	454.415	0,00006	23,5	35,3
2	330	297.013	157.239	139.774	65.843	231.17	0,00006	23,5	35,3
3	330	297.013	157.239	139.774	65.843	231.17	0,00006	23,5	35,3
4	319	287.316	165.948	121.368	64.071	223.245	0,00006	-0,1	-4,3
5	319	287.316	165.948	121.368	64.071	223.245	0,00006	-0,1	-4,3

C	P	PG	PL	P1	PX	
1	90,0%	55,3%	44,7%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	52,9%	47,1%	20,0%	70,1%	1980 R./2004 Inc.
3	90,0%	52,9%	47,1%	20,0%	70,1%	1980 R./1980 Inc.
4	90,1%	57,8%	42,2%	20,1%	70,0%	1980 Ext. R/2004 Inc.
5	90,1%	57,8%	42,2%	20,1%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.331.000	1.009.188	0	1.009.188	590.249	418.939	0,00004	250,8	43
2	1.320.550	998.851	0	998.851	587.733	411.118	0,00004	250,8	43
3	1.320.550	998.851	0	998.851	587.733	411.118	0,00004	250,8	43
4	10.45	10.337	0	10.337	2.516	7.821	0,00004	300,1	10,9
5	10.45	10.337	0	10.337	2.516	7.821	0,00004	300,1	10,9

C	P	PG	PL	P1	PX	
1	75,8%	0,0%	100,0%	44,3%	31,5%	2004 R./2004 Inc.
2	75,6%	0,0%	100,0%	44,5%	31,1%	1980 R./2004 Inc.
3	75,6%	0,0%	100,0%	44,5%	31,1%	1980 R./1980 Inc.
4	98,9%	0,0%	100,0%	24,1%	74,8%	1980 Ext. R/2004 Inc.
5	98,9%	0,0%	100,0%	24,1%	74,8%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.980.000	167.138	30.988	136.15	167.138	0	0,0001	59,6	20,5
2	1.650.550	142.591	8.658	133.933	142.591	0	0,0001	59,6	20,5
3	1.650.550	142.591	8.658	133.933	142.591	0	0,0001	59,6	20,5
4	329.45	24.547	22.33	2.217	24.547	0	0,0001	-0,1	-9,1
5	329.45	24.547	22.33	2.217	24.547	0	0,0001	-0,1	-9,1

C	P	PG	PL	P1	PX	
1	8,4%	18,5%	81,5%	8,4%	0,0%	2004 R./2004 Inc.
2	8,6%	6,1%	93,9%	8,6%	0,0%	1980 R./2004 Inc.
3	8,6%	6,1%	93,9%	8,6%	0,0%	1980 R./1980 Inc.
4	7,5%	91,0%	9,0%	7,5%	0,0%	1980 Ext. R/2004 Inc.
5	7,5%	91,0%	9,0%	7,5%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	649	30.988	30.988	0	30.988	0	0,0001	59,6	20,5
2	330	8.658	8.658	0	8.658	0	0,0001	59,6	20,5
3	330	8.658	8.658	0	8.658	0	0,0001	59,6	20,5
4	319	22.33	22.33	0	22.33	0	0,0001	-0,1	-9,1
5	319	22.33	22.33	0	22.33	0	0,0001	-0,1	-9,1

C	P	PG	PL	P1	PX	
1	4,8%	100,0%	0,0%	4,8%	0,0%	2004 R./2004 Inc.
2	2,6%	100,0%	0,0%	2,6%	0,0%	1980 R./2004 Inc.
3	2,6%	100,0%	0,0%	2,6%	0,0%	1980 R./1980 Inc.
4	7,0%	100,0%	0,0%	7,0%	0,0%	1980 Ext. R/2004 Inc.
5	7,0%	100,0%	0,0%	7,0%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	1.331.000	136.15	0	136.15	136.15	0	0,0001	95	34
2	1.320.550	133.933	0	133.933	133.933	0	0,0001	95	34
3	1.320.550	133.933	0	133.933	133.933	0	0,0001	95	34
4	10.45	2.217	0	2.217	2.217	0	0,0001	300,1	-9,6
5	10.45	2.217	0	2.217	2.217	0	0,0001	300,1	-9,6

C	P	PG	PL	P1	PX	
1	10,2%	0,0%	100,0%	10,2%	0,0%	2004 R./2004 Inc.
2	10,1%	0,0%	100,0%	10,1%	0,0%	1980 R./2004 Inc.
3	10,1%	0,0%	100,0%	10,1%	0,0%	1980 R./1980 Inc.
4	21,2%	0,0%	100,0%	21,2%	0,0%	1980 Ext. R/2004 Inc.
5	21,2%	0,0%	100,0%	21,2%	0,0%	1980 Ext./1980 Inc.



## 1.17. Table 24A – crude oil, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base relative density @ 60 °F:** 0,6112 to 1,1646, increment 0,1

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	19.922.400	15.656.943	5.645.707	10.011.236	4.971.954	10.684.989	0,00021	293,6	0,6128
2	7.510.680	5.361.922	1.618.614	3.743.308	2.270.416	3.091.506	0,00008	4,5	0,7603
3	1.502.136	1.126.037	182.937	943,1	617.175	508.862	0,00006	30,8	0,7915
4	12.411.720	10.295.021	4.027.093	6.267.928	2.701.538	7.593.483	0,00021	293,6	0,6128
5	2.483.064	2.151.660	482.957	1.668.703	627.597	1.524.063	0,00007	-9,1	0,6195

C	P	PG	PL	P1	PX		
1	78,6%	36,1%	63,9%	25,0%	53,6%	2004 R./2004 Inc.	
2	71,4%	30,2%	69,8%	30,2%	41,2%	1980 R./2004 Inc.	
3	75,0%	16,2%	83,8%	41,1%	33,9%	1980 R./1980 Inc.	
4	82,9%	39,1%	60,9%	21,8%	61,2%	1980 Ext. R/2004 Inc.	
5	86,7%	22,4%	77,6%	25,3%	61,4%	1980 Ext./1980 Inc.	

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.530.120	5.885.774	3.323.710	2.562.064	1.282.715	4.603.059	0,00013	-42,2	0,6128
2	1.908.000	1.717.214	914.971	802.243	381.213	1.336.001	0,00008	4,5	0,7603
3	381.6	343.312	182.937	160.375	76.128	267.184	0,00006	30,8	0,7915
4	4.622.120	4.168.560	2.408.739	1.759.821	901.502	3.267.058	0,00013	-42,2	0,6128
5	924.66	832.627	482.957	349.67	184.708	647.919	0,00007	-9,1	0,6195

C	P	PG	PL	P1	PX		
1	90,1%	56,5%	43,5%	19,6%	70,5%	2004 R./2004 Inc.	
2	90,0%	53,3%	46,7%	20,0%	70,0%	1980 R./2004 Inc.	
3	90,0%	53,3%	46,7%	19,9%	70,0%	1980 R./1980 Inc.	
4	90,2%	57,8%	42,2%	19,5%	70,7%	1980 Ext. R/2004 Inc.	
5	90,0%	58,0%	42,0%	20,0%	70,1%	1980 Ext./1980 Inc.	

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.392.280	9.771.169	2.321.997	7.449.172	3.689.239	6.081.930	0,00021	293,6	0,6128
2	5.602.680	3.644.708	703.643	2.941.065	1.889.203	1.755.505	0,00008	227,1	0,8333
3	1.120.536	782.725	0	782.725	541.047	241.678	0,00004	231,1	0,8335
4	7.789.600	6.126.461	1.618.354	4.508.107	1.800.036	4.326.425	0,00021	293,6	0,6128
5	1.558.404	1.319.033	0	1.319.033	442.889	876.144	0,00007	291,5	0,6320

C	P	PG	PL	P1	PX		
1	73,0%	23,8%	76,2%	27,5%	45,4%	2004 R./2004 Inc.	
2	65,1%	19,3%	80,7%	33,7%	31,3%	1980 R./2004 Inc.	
3	69,9%	0,0%	100,0%	48,3%	21,6%	1980 R./1980 Inc.	
4	78,6%	26,4%	73,6%	23,1%	55,5%	1980 Ext. R/2004 Inc.	
5	84,6%	0,0%	100,0%	28,4%	56,2%	1980 Ext./1980 Inc.	



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	19.922.400	3.315.128	924.858	2.390.270	3.235.206	79.922	0,0003	298,3	0,6208
2	7.510.680	701.867	125.915	575.952	701.867	0	0,0001	59,9	0,8268
3	1.502.136	99.728	11.268	88.46	99.728	0	0,0001	59,2	0,7795
4	12.411.720	2.613.261	798.943	1.814.318	2.533.339	79.922	0,0003	298,3	0,6208
5	2.483.064	342.234	66.696	275.538	342.234	0	0,0001	59,6	0,6250

C	P	PG	PL	P1	PX	
1	16,6%	27,9%	72,1%	16,2%	0,0%	2004 R./2004 Inc.
2	9,3%	17,9%	82,1%	9,3%	0,0%	1980 R./2004 Inc.
3	6,6%	11,3%	88,7%	6,6%	0,0%	1980 R./1980 Inc.
4	21,1%	30,6%	69,4%	20,4%	0,0%	1980 Ext. R/2004 Inc.
5	13,8%	19,5%	80,5%	13,8%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.530.120	628.452	509.401	119.051	628.452	0	0,0001	59,9	0,8268
2	1.908.000	78.752	67.408	11.344	78.752	0	0,0001	59,9	0,8268
3	381.6	11.268	11.268	0	11.268	0	0,0001	59,2	0,7795
4	4.622.120	549.7	441.993	107.707	549.7	0	0,0001	59,8	0,6752
5	924.66	66.696	66.696	0	66.696	0	0,0001	59,6	0,6250

C	P	PG	PL	P1	PX	
1	9,6%	81,1%	18,9%	9,6%	0,0%	2004 R./2004 Inc.
2	4,1%	85,6%	14,4%	4,1%	0,0%	1980 R./2004 Inc.
3	3,0%	100,0%	0,0%	3,0%	0,0%	1980 R./1980 Inc.
4	11,9%	80,4%	19,6%	11,9%	0,0%	1980 Ext. R/2004 Inc.
5	7,2%	100,0%	0,0%	7,2%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.392.280	2.686.676	415.457	2.271.219	2.606.754	79.922	0,0003	298,3	0,6208
2	5.602.680	623.115	58.507	564.608	623.115	0	0,0001	71,4	0,7603
3	1.120.536	88.46	0	88.46	88.46	0	0,0001	89,4	0,7835
4	7.789.600	2.063.561	356.95	1.706.611	1.983.639	79.922	0,0003	298,3	0,6208
5	1.558.404	275.538	0	275.538	275.538	0	0,0001	80,5	0,6130

C	P	PG	PL	P1	PX	
1	20,1%	15,5%	84,5%	19,5%	0,6%	2004 R./2004 Inc.
2	11,1%	9,4%	90,6%	11,1%	0,0%	1980 R./2004 Inc.
3	7,9%	0,0%	100,0%	7,9%	0,0%	1980 R./1980 Inc.
4	26,5%	17,3%	82,7%	25,5%	1,0%	1980 Ext. R/2004 Inc.
5	17,7%	0,0%	100,0%	17,7%	0,0%	1980 Ext./1980 Inc.



## 1.18. Table 24B – products, 60 °F base temperature – detailed results

**Comparison grid:**

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base relative density @ 60 °F:** 0,6112 to 1,1646, increment 0,1

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

**Absolute numbers:**

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

**Calculated % ratios:**

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	19.922.400	15.484.582	4.771.300	10.713.282	5.062.245	10.422.337	0,00037	297,3	0,7718
2	9.091.730	6.440.188	1.694.479	4.745.709	2.707.300	3.732.888	0,00021	197,7	0,7813
3	1.818.346	1.392.532	246.364	1.146.168	745.866	646.666	0,00006	37,1	0,7015
4	10.830.670	9.044.394	3.076.821	5.967.573	2.354.945	6.689.449	0,00037	297,3	0,7718
5	2.166.854	1.940.274	423.568	1.516.706	487.819	1.452.455	0,00007	-4,5	0,6205

C	P	PG	PL	P1	PX	
1	77,7%	30,8%	69,2%	25,4%	52,3%	2004 R./2004 Inc.
2	70,8%	26,3%	73,7%	29,8%	41,1%	1980 R./2004 Inc.
3	76,6%	17,7%	82,3%	41,0%	35,6%	1980 R./1980 Inc.
4	83,5%	34,0%	66,0%	21,7%	61,8%	1980 Ext. R/2004 Inc.
5	89,5%	21,8%	78,2%	22,5%	67,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.530.120	5.889.107	3.345.072	2.544.035	1.276.009	4.613.098	0,00020	-47,8	0,7733
2	2.538.000	2.285.873	1.231.673	1.054.200	504.029	1.781.844	0,00013	6,1	0,7718
3	507.6	456.842	246.364	210.478	101.175	355.667	0,00006	37,1	0,7015
4	3.992.120	3.603.234	2.113.399	1.489.835	771.98	2.831.254	0,00020	-47,8	0,7733
5	798.66	718.685	423.568	295.117	159.404	559.281	0,00007	-4,5	0,6205

C	P	PG	PL	P1	PX	
1	90,2%	56,8%	43,2%	19,5%	70,6%	2004 R./2004 Inc.
2	90,1%	53,9%	46,1%	19,9%	70,2%	1980 R./2004 Inc.
3	90,0%	53,9%	46,1%	19,9%	70,1%	1980 R./1980 Inc.
4	90,3%	58,7%	41,3%	19,3%	70,9%	1980 Ext. R/2004 Inc.
5	90,0%	58,9%	41,1%	20,0%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.392.280	9.595.475	1.426.228	8.169.247	3.786.236	5.809.239	0,00037	297,3	0,7718
2	6.553.730	4.154.315	462.806	3.691.509	2.203.271	1.951.044	0,00021	197,7	0,7813
3	1.310.746	935.69	0	935.69	644.691	290.999	0,00004	240,6	0,8440
4	6.838.550	5.441.160	963.422	4.477.738	1.582.965	3.858.195	0,00037	297,3	0,7718
5	1.368.194	1.221.589	0	1.221.589	328.415	893.174	0,00007	277,8	0,6125

C	P	PG	PL	P1	PX	
1	71,6%	14,9%	85,1%	28,3%	43,4%	2004 R./2004 Inc.
2	63,4%	11,1%	88,9%	33,6%	29,8%	1980 R./2004 Inc.
3	71,4%	0,0%	100,0%	49,2%	22,2%	1980 R./1980 Inc.
4	79,6%	17,7%	82,3%	23,1%	56,4%	1980 Ext. R/2004 Inc.
5	89,3%	0,0%	100,0%	24,0%	65,3%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	19.922.400	3.170.265	827.456	2.342.809	3.019.060	151.205	0,0004	261,1	0,7733
2	9.091.730	835.047	173.027	662.02	825.04	10.007	0,0003	199,0	0,7813
3	1.818.346	125.247	17.955	107.292	125.247	0	0,0001	59,6	0,9990
4	10.830.670	2.335.218	654.429	1.680.789	2.194.020	141.198	0,0004	261,1	0,7733
5	2.166.854	345.649	64.332	281.317	345.649	0	0,0001	59,0	0,6410

C	P	PG	PL	P1	PX	
1	15,9%	26,1%	73,9%	15,2%	0,8%	2004 R./2004 Inc.
2	9,2%	20,7%	79,3%	9,1%	0,1%	1980 R./2004 Inc.
3	6,9%	14,3%	85,7%	6,9%	0,0%	1980 R./1980 Inc.
4	21,6%	28,0%	72,0%	20,3%	1,3%	1980 Ext. R/2004 Inc.
5	16,0%	18,6%	81,4%	16,0%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	6.530.120	608.053	507.936	100.117	602.855	5.198	0,0002	-14,3	0,7718
2	2.538.000	130.953	109.986	20.967	130.953	0	0,0001	59,9	0,8137
3	507.6	17.955	17.955	0	17.955	0	0,0001	59,6	0,9990
4	3.992.120	477.1	397.95	79.15	471.902	5.198	0,0002	-14,3	0,7718
5	798.66	64.332	64.332	0	64.332	0	0,0001	59,0	0,6410

C	P	PG	PL	P1	PX	
1	9,3%	83,5%	16,5%	9,2%	0,1%	2004 R./2004 Inc.
2	5,2%	84,0%	16,0%	5,2%	0,0%	1980 R./2004 Inc.
3	3,5%	100,0%	0,0%	3,5%	0,0%	1980 R./1980 Inc.
4	12,0%	83,4%	16,6%	11,8%	0,1%	1980 Ext. R/2004 Inc.
5	8,1%	100,0%	0,0%	8,1%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.392.280	2.562.212	319.52	2.242.692	2.416.205	146.007	0,0004	261,1	0,7733
2	6.553.730	704.094	63.041	641.053	694.087	10.007	0,0003	199	0,7813
3	1.310.746	107.292	0	107.292	107.292	0	0,0001	81	0,6780
4	6.838.550	1.858.118	256.479	1.601.639	1.722.118	136	0,0004	261,1	0,7733
5	1.368.194	281.317	0	281.317	281.317	0	0,0001	80,1	0,6275

C	P	PG	PL	P1	PX	
1	19,1%	12,5%	87,5%	18,0%	1,1%	2004 R./2004 Inc.
2	10,7%	9,0%	91,0%	10,6%	0,2%	1980 R./2004 Inc.
3	8,2%	0,0%	100,0%	8,2%	0,0%	1980 R./1980 Inc.
4	27,2%	13,8%	86,2%	25,2%	2,0%	1980 Ext. R/2004 Inc.
5	20,6%	0,0%	100,0%	20,6%	0,0%	1980 Ext./1980 Inc.



## 1.19. Table 24C – special applications, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Thermal expansion coefficient @ 60 °F:** 0,0002300 1 /°F to 0,0009300 1/ °F, increment 0,0000001

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**TTLCB:** Thermal expansion coefficient for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	25.203.600	20.210.183	6.121.479	14.088.704	6.055.477	14.154.706	0,00011	283,5	0,0009297
2	12.416.103	8.983.323	2.746.734	6.236.589	3.569.434	5.413.889	0,00007	23,8	0,0008892
3	2.483.821	1.948.325	391.504	1.556.821	1.012.810	935.515	0,00006	37,9	0,0009130
4	12.787.497	11.226.860	3.374.745	7.852.115	2.486.043	8.740.817	0,00011	283,5	0,0009297
5	2.559.779	2.413.878	479.221	1.934.657	339.225	2.074.653	0,00007	-12,6	0,0009140

C	P	PG	PL	P1	PX	
1	80,2%	30,3%	69,7%	24,0%	56,2%	2004 R./2004 Inc.
2	72,4%	30,6%	69,4%	28,7%	43,6%	1980 R./2004 Inc.
3	78,4%	20,1%	79,9%	40,8%	37,7%	1980 R./1980 Inc.
4	87,8%	30,1%	69,9%	19,4%	68,4%	1980 Ext. R/2004 Inc.
5	94,3%	19,9%	80,1%	13,3%	81,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	8.261.180	7.436.238	4.350.481	3.085.757	1.647.720	5.788.518	0,00009	-32,0	0,0009242
2	3.961.800	3.566.764	1.957.011	1.609.753	791.538	2.775.226	0,00007	23,8	0,0008892
3	792.6	713.542	391.504	322.038	158.088	555.454	0,00006	37,9	0,0009130
4	4.299.380	3.869.474	2.393.470	1.476.004	856.182	3.013.292	0,00009	-32,0	0,0009242
5	860.58	774.441	479.221	295.22	171.806	602.635	0,00007	-12,6	0,0009140

C	P	PG	PL	P1	PX	
1	90,0%	58,5%	41,5%	19,9%	70,1%	2004 R./2004 Inc.
2	90,0%	54,9%	45,1%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	54,9%	45,1%	19,9%	70,1%	1980 R./1980 Inc.
4	90,0%	61,9%	38,1%	19,9%	70,1%	1980 Ext. R/2004 Inc.
5	90,0%	61,9%	38,1%	20,0%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	16.942.420	12.773.945	1.770.998	11.002.947	4.407.757	8.366.188	0,00011	283,5	0,0009297
2	8.454.303	5.416.559	789.723	4.626.836	2.777.896	2.638.663	0,00007	235,1	0,0005097
3	1.691.221	1.234.783	0	1.234.783	854.722	380.061	0,00003	136,6	0,0009275
4	8.488.117	7.357.386	981.275	6.376.111	1.629.861	5.727.525	0,00011	283,5	0,0009297
5	1.699.199	1.639.437	0	1.639.437	167.419	1.472.018	0,00006	263,5	0,0009280

C	P	PG	PL	P1	PX	
1	75,4%	13,9%	86,1%	26,0%	49,4%	2004 R./2004 Inc.
2	64,1%	14,6%	85,4%	32,9%	31,2%	1980 R./2004 Inc.
3	73,0%	0,0%	100,0%	50,5%	22,5%	1980 R./1980 Inc.
4	86,7%	13,3%	86,7%	19,2%	67,5%	1980 Ext. R/2004 Inc.
5	96,5%	0,0%	100,0%	9,9%	86,6%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	25.203.600	4.312.975	903.77	3.409.205	4.312.428	547	0,0002	284,6	0,0009247
2	12.416.103	1.115.449	262.639	852.81	1.115.449	0	0,0001	59,9	0,0004998
3	2.483.821	175.994	35.039	140.955	175.994	0	0,0001	59,8	0,0007500
4	12.787.497	3.197.526	641.131	2.556.395	3.196.979	547	0,0002	284,6	0,0009247
5	2.559.779	564.513	92.032	472.481	564.513	0	0,0001	59,4	0,0002500

C	P	PG	PL	P1	PX	
1	17,1%	21,0%	79,0%	17,1%	0,0%	2004 R./2004 Inc.
2	9,0%	23,5%	76,5%	9,0%	0,0%	1980 R./2004 Inc.
3	7,1%	19,9%	80,1%	7,1%	0,0%	1980 R./1980 Inc.
4	25,0%	20,1%	79,9%	25,0%	0,0%	1980 Ext. R/2004 Inc.
5	22,1%	16,3%	83,7%	22,1%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	8.261.180	774.494	703.931	70.563	774.494	0	0,0001	59,9	0,0004998
2	3.961.800	202.082	188.415	13.667	202.082	0	0,0001	59,9	0,0004998
3	792.6	35.039	35.039	0	35.039	0	0,0001	59,8	0,0007500
4	4.299.380	572.412	515.516	56.896	572.412	0	0,0001	59,8	0,0002498
5	860.58	92.032	92.032	0	92.032	0	0,0001	59,4	0,0002500

C	P	PG	PL	P1	PX	
1	9,4%	90,9%	9,1%	9,4%	0,0%	2004 R./2004 Inc.
2	5,1%	93,2%	6,8%	5,1%	0,0%	1980 R./2004 Inc.
3	4,4%	100,0%	0,0%	4,4%	0,0%	1980 R./1980 Inc.
4	13,3%	90,1%	9,9%	13,3%	0,0%	1980 Ext. R/2004 Inc.
5	10,7%	100,0%	0,0%	10,7%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	TTLCB
1	16.942.420	3.538.481	199.839	3.338.642	3.537.934	547	0,0002	284,6	0,0009247
2	8.454.303	913.367	74.224	839.143	913.367	0	0,0001	71,7	0,0008987
3	1.691.221	140.955	0	140.955	140.955	0	0,0001	80,9	0,0009160
4	8.488.117	2.625.114	125.615	2.499.499	2.624.567	547	0,0002	284,6	0,0009247
5	1.699.199	472.481	0	472.481	472.481	0	0,0001	134,3	0,0002550

C	P	PG	PL	P1	PX	
1	20,9%	5,6%	94,4%	20,9%	0,0%	2004 R./2004 Inc.
2	10,8%	8,1%	91,9%	10,8%	0,0%	1980 R./2004 Inc.
3	8,3%	0,0%	100,0%	8,3%	0,0%	1980 R./1980 Inc.
4	30,9%	4,8%	95,2%	30,9%	0,0%	1980 Ext. R/2004 Inc.
5	27,8%	0,0%	100,0%	27,8%	0,0%	1980 Ext./1980 Inc.



## 1.20. Table 24D – lubricants, 60 °F base temperature – detailed results

### Comparison grid:

**Observed temperature:** -58 °F to 302 °F, increment 0,1 °F

**Base relative density @ 60 °F:** 0,8017 to 1,1646, increment 0,1

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations – 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations – 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations – deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations – deviation above one result grid increment:  $(NDG1 / NSC) * 100$



VCF - 5 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.068.000	9.695.454	2.264.580	7.430.874	4.019.280	5.676.174	0,00008	-53,7	0,8023
2	10.881.626	7.731.180	1.171.593	6.559.587	3.576.116	4.155.064	0,00007	284,9	0,8023
3	2.175.725	1.692.124	206.948	1.485.176	871.21	820.914	0,00006	23,6	0,8185
4	2.186.374	1.964.274	1.092.987	871.287	443.164	1.521.110	0,00008	-53,7	0,8023
5	437.875	394.946	218.11	176.836	89.268	305.678	0,00006	-0,1	0,8145

C	P	PG	PL	P1	PX	
1	74,2%	23,4%	76,6%	30,8%	43,4%	2004 R./2004 Inc.
2	71,0%	15,2%	84,8%	32,9%	38,2%	1980 R./2004 Inc.
3	77,8%	12,2%	87,8%	40,0%	37,7%	1980 R./1980 Inc.
4	89,8%	55,6%	44,4%	20,3%	69,6%	1980 Ext. R/2004 Inc.
5	90,2%	55,2%	44,8%	20,4%	69,8%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.283.400	3.855.428	2.124.914	1.730.514	855.755	2.999.673	0,00008	-53,7	0,8023
2	2.175.600	1.958.355	1.035.003	923.352	434.149	1.524.206	0,00006	39,6	0,8023
3	435	391.595	206.948	184.647	86.78	304.815	0,00006	23,6	0,8185
4	2.107.800	1.897.073	1.089.911	807.162	421.606	1.475.467	0,00008	-53,7	0,8023
5	421.68	379.56	218.11	161.45	84.563	294.997	0,00006	-0,1	0,8145

C	P	PG	PL	P1	PX	
1	90,0%	55,1%	44,9%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	52,9%	47,1%	20,0%	70,1%	1980 R./2004 Inc.
3	90,0%	52,8%	47,2%	19,9%	70,1%	1980 R./1980 Inc.
4	90,0%	57,5%	42,5%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	57,5%	42,5%	20,1%	70,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	8.784.600	5.840.026	139.666	5.700.360	3.163.525	2.676.501	0,00007	284,9	0,8023
2	8.706.026	5.772.825	136.59	5.636.235	3.141.967	2.630.858	0,00007	284,9	0,8023
3	1.740.725	1.300.529	0	1.300.529	784.43	516.099	0,00004	250,4	0,8025
4	78.574	67.201	3.076	64.125	21.558	45.643	0,00007	300,1	0,8023
5	16.195	15.386	0	15.386	4.705	10.681	0,00004	300,1	0,8025

C	P	PG	PL	P1	PX	
1	66,5%	2,4%	97,6%	36,0%	30,5%	2004 R./2004 Inc.
2	66,3%	2,4%	97,6%	36,1%	30,2%	1980 R./2004 Inc.
3	74,7%	0,0%	100,0%	45,1%	29,6%	1980 R./1980 Inc.
4	85,5%	4,6%	95,4%	27,4%	58,1%	1980 Ext. R/2004 Inc.
5	95,0%	0,0%	100,0%	29,1%	66,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	13.068.000	1.099.774	205.595	894.179	1.099.774	0	0,0001	59,6	0,9308
2	10.881.626	934.143	59.665	874.478	934.143	0	0,0001	59,6	0,9308
3	2.175.725	181.681	11.058	170.623	181.681	0	0,0001	59,6	0,9310
4	2.186.374	165.631	145.93	19.701	165.631	0	0,0001	43,8	11,643
5	437.875	31.256	28.227	3.029	31.256	0	0,0001	43,8	11,645

C	P	PG	PL	P1	PX	
1	8,4%	18,7%	81,3%	8,4%	0,0%	2004 R./2004 Inc.
2	8,6%	6,4%	93,6%	8,6%	0,0%	1980 R./2004 Inc.
3	8,4%	6,1%	93,9%	8,4%	0,0%	1980 R./1980 Inc.
4	7,6%	88,1%	11,9%	7,6%	0,0%	1980 Ext. R/2004 Inc.
5	7,1%	90,3%	9,7%	7,1%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.283.400	207.578	202.166	5.412	207.578	0	0,0001	59,6	0,9308
2	2.175.600	57.418	56.426	992	57.418	0	0,0001	59,6	0,9308
3	435	11.058	11.058	0	11.058	0	0,0001	59,6	0,9310
4	2.107.800	150.16	145.74	4.42	150.16	0	0,0001	43,8	11,643
5	421.68	28.227	28.227	0	28.227	0	0,0001	43,8	11,645

C	P	PG	PL	P1	PX	
1	4,8%	97,4%	2,6%	4,8%	0,0%	2004 R./2004 Inc.
2	2,6%	98,3%	1,7%	2,6%	0,0%	1980 R./2004 Inc.
3	2,5%	100,0%	0,0%	2,5%	0,0%	1980 R./1980 Inc.
4	7,1%	97,1%	2,9%	7,1%	0,0%	1980 Ext. R/2004 Inc.
5	6,7%	100,0%	0,0%	6,7%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	8.784.600	892.196	3.429	888.767	892.196	0	0,0001	81,9	0,8473
2	8.706.026	876.725	3.239	873.486	876.725	0	0,0001	81,9	0,8473
3	1.740.725	170.623	0	170.623	170.623	0	0,0001	93,3	0,8430
4	78.574	15.471	190	15.281	15.471	0	0,0001	102,7	11,643
5	16.195	3.029	0	3.029	3.029	0	0,0001	121,2	11,645

C	P	PG	PL	P1	PX	
1	10,2%	0,4%	99,6%	10,2%	0,0%	2004 R./2004 Inc.
2	10,1%	0,4%	99,6%	10,1%	0,0%	1980 R./2004 Inc.
3	9,8%	0,0%	100,0%	9,8%	0,0%	1980 R./1980 Inc.
4	19,7%	1,2%	98,8%	19,7%	0,0%	1980 Ext. R/2004 Inc.
5	18,7%	0,0%	100,0%	18,7%	0,0%	1980 Ext./1980 Inc.



## 1.21. Table 54A – crude oil, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 15 °C:** 611,2 kg/m<sup>3</sup> to 1.163,8 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.109.526	18.106.150	3.994.035	14.112.115	4.552.738	13.553.412	0,00039	149,60	611,3
2	8.241.175	6.173.591	1.071.145	5.102.446	2.036.112	4.137.479	0,00011	114,85	827,8
3	1.648.235	1.402.621	208.897	1.193.724	459.273	943.348	0,00006	4,20	763,0
4	13.868.351	11.932.559	2.922.890	9.009.669	2.516.626	9.415.933	0,00039	149,60	611,3
5	2.772.870	2.536.446	580.706	1.955.740	456.848	2.079.598	0,00023	145,15	611,5

C	P	PG	PL	P1	PX	
1	81,9%	22,1%	77,9%	20,6%	61,3%	2004 R./2004 Inc.
2	74,9%	17,4%	82,6%	24,7%	50,2%	1980 R./2004 Inc.
3	85,1%	14,9%	85,1%	27,9%	57,2%	1980 R./1980 Inc.
4	86,0%	24,5%	75,5%	18,1%	67,9%	1980 Ext. R/2004 Inc.
5	91,5%	22,9%	77,1%	16,5%	75,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.183.800	6.483.333	3.935.632	2.547.701	1.390.761	5.092.572	0,00014	-41,35	611,3
2	2.095.500	1.886.173	1.044.804	841.369	418.663	1.467.510	0,00008	-10,55	762,3
3	419.1	377.234	208.897	168.337	83.84	293.394	0,00006	4,20	763,0
4	5.088.300	4.597.160	2.890.828	1.706.332	972.098	3.625.062	0,00014	-41,35	611,3
5	1.017.400	915.833	580.706	335.127	203.14	712.693	0,00008	-19,70	614,5

C	P	PG	PL	P1	PX	
1	90,2%	60,7%	39,3%	19,4%	70,9%	2004 R./2004 Inc.
2	90,0%	55,4%	44,6%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	55,4%	44,6%	20,0%	70,0%	1980 R./1980 Inc.
4	90,3%	62,9%	37,1%	19,1%	71,2%	1980 Ext. R/2004 Inc.
5	90,0%	63,4%	36,6%	20,0%	70,1%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.925.726	11.622.817	58.403	11.564.414	3.161.977	8.460.840	0,00039	149,60	611,3
2	6.145.675	4.287.418	26.341	4.261.077	1.617.449	2.669.969	0,00011	114,85	827,8
3	1.229.135	1.025.387	0	1.025.387	375.433	649.954	0,00006	106,80	828,0
4	8.780.051	7.335.399	32.062	7.303.337	1.544.528	5.790.871	0,00039	149,60	611,3
5	1.755.470	1.620.613	0	1.620.613	253.708	1.366.905	0,00023	145,15	611,5

C	P	PG	PL	P1	PX	
1	77,9%	0,5%	99,5%	21,2%	56,7%	2004 R./2004 Inc.
2	69,8%	0,6%	99,4%	26,3%	43,4%	1980 R./2004 Inc.
3	83,4%	0,0%	100,0%	30,5%	52,9%	1980 R./1980 Inc.
4	83,5%	0,4%	99,6%	17,6%	66,0%	1980 Ext. R/2004 Inc.
5	92,3%	0,0%	100,0%	14,5%	77,9%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.109.526	5.306.362	768.59	4.537.772	4.708.135	598.227	0,0004	124,25	611,3
2	8.241.175	1.122.293	104.419	1.017.874	1.122.283	10	0,0002	115,80	827,8
3	1.648.235	223.404	20.31	203.094	223.404	0	0,0001	14,70	858,5
4	13.868.351	4.184.069	664.171	3.519.898	3.585.852	598.217	0,0004	124,25	611,3
5	2.772.870	888.344	123.054	765.29	818.263	70.081	0,0003	135,85	613,5

C	P	PG	PL	P1	PX	
1	24,0%	14,5%	85,5%	21,3%	2,7%	2004 R./2004 Inc.
2	13,6%	9,3%	90,7%	13,6%	0,0%	1980 R./2004 Inc.
3	13,6%	9,1%	90,9%	13,6%	0,0%	1980 R./1980 Inc.
4	30,2%	15,9%	84,1%	25,9%	4,3%	1980 Ext. R/2004 Inc.
5	32,0%	13,9%	86,1%	29,5%	2,5%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.183.800	821.449	768.59	52.859	821.449	0	0,0001	14,90	639,8
2	2.095.500	107.549	104.419	3.13	107.549	0	0,0001	14,80	904,8
3	419.1	20.31	20.31	0	20.31	0	0,0001	14,70	858,5
4	5.088.300	713.9	664.171	49.729	713.9	0	0,0001	14,90	639,8
5	1.017.400	123.054	123.054	0	123.054	0	0,0001	14,70	725,5

C	P	PG	PL	P1	PX	
1	11,4%	93,6%	6,4%	11,4%	0,0%	2004 R./2004 Inc.
2	5,1%	97,1%	2,9%	5,1%	0,0%	1980 R./2004 Inc.
3	4,8%	100,0%	0,0%	4,8%	0,0%	1980 R./1980 Inc.
4	14,0%	93,0%	7,0%	14,0%	0,0%	1980 Ext. R/2004 Inc.
5	12,1%	100,0%	0,0%	12,1%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.925.726	4.484.913	0	4.484.913	3.886.686	598.227	0,0004	124,25	611,3
2	6.145.675	1.014.744	0	1.014.744	1.014.734	10	0,0002	115,80	827,8
3	1.229.135	203.094	0	203.094	203.094	0	0,0001	24,45	772,5
4	8.780.051	3.470.169	0	3.470.169	2.871.952	598.217	0,0004	124,25	611,3
5	1.755.470	765.29	0	765.29	695.209	70.081	0,0003	135,85	613,5

C	P	PG	PL	P1	PX	
1	30,0%	0,0%	100,0%	26,0%	4,0%	2004 R./2004 Inc.
2	16,5%	0,0%	100,0%	16,5%	0,0%	1980 R./2004 Inc.
3	16,5%	0,0%	100,0%	16,5%	0,0%	1980 R./1980 Inc.
4	39,5%	0,0%	100,0%	32,7%	6,8%	1980 Ext. R/2004 Inc.
5	43,6%	0,0%	100,0%	39,6%	4,0%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.109.526	19.694.494	3.949.814	15.744.680	4.585.282	15.109.212	0,00024	149,30	611,2
2	8.234.931	7.008.322	1.043.348	5.964.974	2.290.855	4.717.467	0,00007	-17,60	764,7
3	8.234.931	7.008.322	1.043.348	5.964.974	2.290.855	4.717.467	0,00007	-17,60	764,7
4	13.874.595	12.686.172	2.906.466	9.779.706	2.294.427	10.391.745	0,00024	149,30	611,2
5	13.874.595	12.686.172	2.906.466	9.779.706	2.294.427	10.391.745	0,00024	149,30	611,2

C	P	PG	PL	P1	PX	
1	89,1%	20,1%	79,9%	20,7%	68,3%	2004 R./2004 Inc.
2	85,1%	14,9%	85,1%	27,8%	57,3%	1980 R./2004 Inc.
3	85,1%	14,9%	85,1%	27,8%	57,3%	1980 R./1980 Inc.
4	91,4%	22,9%	77,1%	16,5%	74,9%	1980 Ext. R/2004 Inc.
5	91,4%	22,9%	77,1%	16,5%	74,9%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.183.800	6.465.581	3.949.814	2.515.767	1.434.442	5.031.139	0,00008	-19,70	614,5
2	2.092.860	1.883.797	1.043.348	840.449	418.14	1.465.657	0,00007	-17,60	764,7
3	2.092.860	1.883.797	1.043.348	840.449	418.14	1.465.657	0,00007	-17,60	764,7
4	5.090.940	4.581.784	2.906.466	1.675.318	1.016.302	3.565.482	0,00008	-19,70	614,5
5	5.090.940	4.581.784	2.906.466	1.675.318	1.016.302	3.565.482	0,00008	-19,70	614,5

C	P	PG	PL	P1	PX	
1	90,0%	61,1%	38,9%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	55,4%	44,6%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	55,4%	44,6%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	63,4%	36,6%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	63,4%	36,6%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.925.726	13.228.913	0	13.228.913	3.150.840	10.078.073	0,00024	149,30	611,2
2	6.142.071	5.124.525	0	5.124.525	1.872.715	3.251.810	0,00006	105,15	824,6
3	6.142.071	5.124.525	0	5.124.525	1.872.715	3.251.810	0,00006	105,15	824,6
4	8.783.655	8.104.388	0	8.104.388	1.278.125	6.826.263	0,00024	149,30	611,2
5	8.783.655	8.104.388	0	8.104.388	1.278.125	6.826.263	0,00024	145,15	611,5

C	P	PG	PL	P1	PX	
1	88,6%	0,0%	100,0%	21,1%	67,5%	2004 R./2004 Inc.
2	83,4%	0,0%	100,0%	30,5%	52,9%	1980 R./2004 Inc.
3	83,4%	0,0%	100,0%	30,5%	52,9%	1980 R./1980 Inc.
4	92,3%	0,0%	100,0%	14,6%	77,7%	1980 Ext. R/2004 Inc.
5	92,3%	0,0%	100,0%	14,6%	77,7%	1980 Ext./1980 Inc.

VCF - 4 decimals

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.109.526	5.562.797	716.705	4.846.092	5.208.171	354.626	0,0003	135,70	611,2
2	8.234.931	1.118.103	101.019	1.017.084	1.118.103	0	0,0001	14,95	783,6
3	8.234.931	1.118.103	101.019	1.017.084	1.118.103	0	0,0001	14,95	783,6
4	13.874.595	4.444.694	615.686	3.829.008	4.090.068	354.626	0,0003	135,70	611,2
5	13.874.595	4.444.694	615.686	3.829.008	4.090.068	354.626	0,0003	135,70	611,2

C	P	PG	PL	P1	PX	
1	25,2%	12,9%	87,1%	23,6%	1,6%	2004 R./2004 Inc.
2	13,6%	9,0%	91,0%	13,6%	0,0%	1980 R./2004 Inc.
3	13,6%	9,0%	91,0%	13,6%	0,0%	1980 R./1980 Inc.
4	32,0%	13,9%	86,1%	29,5%	2,6%	1980 Ext. R/2004 Inc.
5	32,0%	13,9%	86,1%	29,5%	2,6%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.183.800	716.705	716.705	716.705	0	0,0001	14,95	783,6	716.705
2	2.092.860	101.019	101.019	101.019	0	0,0001	14,95	783,6	101.019
3	2.092.860	101.019	101.019	101.019	0	0,0001	14,95	783,6	101.019
4	5.090.940	615.686	615.686	615.686	0	0,0001	14,90	639,8	615.686
5	5.090.940	615.686	615.686	615.686	0	0,0001	14,90	639,8	615.686

C	P	PG	PL	P1	PX	
1	10,0%	100,0%	0,0%	10,0%	0,0%	2004 R./2004 Inc.
2	4,8%	100,0%	0,0%	4,8%	0,0%	1980 R./2004 Inc.
3	4,8%	100,0%	0,0%	4,8%	0,0%	1980 R./1980 Inc.
4	12,1%	100,0%	0,0%	12,1%	0,0%	1980 Ext. R/2004 Inc.
5	12,1%	100,0%	0,0%	12,1%	0,0%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.925.726	4.846.092	0	4.846.092	4.491.466	354.626	0,0003	135,70	611,2
2	6.142.071	1.017.084	0	1.017.084	1.017.084	0	0,0001	23,95	759,8
3	6.142.071	1.017.084	0	1.017.084	1.017.084	0	0,0001	23,95	759,8
4	8.783.655	3.829.008	0	3.829.008	3.474.382	354.626	0,0003	135,70	611,2
5	8.783.655	3.829.008	0	3.829.008	3.474.382	354.626	0,0003	135,85	613,5

C	P	PG	PL	P1	PX	
1	32,5%	0,0%	100,0%	30,1%	2,4%	2004 R./2004 Inc.
2	16,6%	0,0%	100,0%	16,6%	0,0%	1980 R./2004 Inc.
3	16,6%	0,0%	100,0%	16,6%	0,0%	1980 R./1980 Inc.
4	43,6%	0,0%	100,0%	39,6%	4,0%	1980 Ext. R/2004 Inc.
5	43,6%	0,0%	100,0%	39,6%	4,0%	1980 Ext./1980 Inc.



## 1.22. Table 54B – products, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 15 °C:** 611,2 kg/m<sup>3</sup> to 1.163,9 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDD1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDD1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.113.527	16.611.391	4.621.878	11.989.513	5.543.633	11.067.758	0,00105	149,95	771,3
2	9.880.225	6.671.684	1.932.045	4.739.639	2.896.755	3.774.929	0,00053	88,40	778,8
3	1.976.045	1.371.607	273.52	1.098.087	729.115	642.492	0,00036	88,95	779,0
4	12.233.302	9.939.707	2.689.833	7.249.874	2.646.878	7.292.829	0,00105	149,95	771,3
5	2.445.060	2.120.501	431.603	1.688.898	580.245	1.540.256	0,00072	149,95	771,5

C	P	PG	PL	P1	PX	
1	75,1%	27,8%	72,2%	25,1%	50,0%	2004 R./2004 Inc.
2	67,5%	29,0%	71,0%	29,3%	38,2%	1980 R./2004 Inc.
3	69,4%	19,9%	80,1%	36,9%	32,5%	1980 R./1980 Inc.
4	81,3%	27,1%	72,9%	21,6%	59,6%	1980 Ext. R/2004 Inc.
5	86,7%	20,4%	79,6%	23,7%	63,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.185.100	6.485.874	3.524.152	2.961.722	1.394.981	5.090.893	0,00047	-48,75	771,3
2	2.788.500	2.516.809	1.365.380	1.151.429	543.652	1.973.157	0,00027	-16,55	771,3
3	557.7	503.62	273.52	230.1	108.457	395.163	0,00020	-16,55	771,5
4	4.396.600	3.969.065	2.158.772	1.810.293	851.329	3.117.736	0,00047	-48,75	771,3
5	878.8	793.334	431.603	361.731	171.449	621.885	0,00033	-48,70	771,0

C	P	PG	PL	P1	PX	
1	90,3%	54,3%	45,7%	19,4%	70,9%	2004 R./2004 Inc.
2	90,3%	54,3%	45,7%	19,5%	70,8%	1980 R./2004 Inc.
3	90,3%	54,3%	45,7%	19,4%	70,9%	1980 R./1980 Inc.
4	90,3%	54,4%	45,6%	19,4%	70,9%	1980 Ext. R/2004 Inc.
5	90,3%	54,4%	45,6%	19,5%	70,8%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.928.427	10.125.517	1.097.726	9.027.791	4.148.652	5.976.865	0,00105	149,95	771,3
2	7.091.725	4.154.875	566.665	3.588.210	2.353.103	1.801.772	0,00053	88,40	778,8
3	1.418.345	867.987	0	867.987	620.658	247.329	0,00036	88,95	779,0
4	7.836.702	5.970.642	531.061	5.439.581	1.795.549	4.175.093	0,00105	149,95	771,3
5	1.566.260	1.327.167	0	1.327.167	408.796	918.371	0,00072	149,95	771,5

C	P	PG	PL	P1	PX	
1	67,8%	10,8%	89,2%	27,8%	40,0%	2004 R./2004 Inc.
2	58,6%	13,6%	86,4%	33,2%	25,4%	1980 R./2004 Inc.
3	61,2%	0,0%	100,0%	43,8%	17,4%	1980 R./1980 Inc.
4	76,2%	8,9%	91,1%	22,9%	53,3%	1980 Ext. R/2004 Inc.
5	84,7%	0,0%	100,0%	26,1%	58,6%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.113.527	3.887.834	564.962	3.322.872	3.231.564	656.27	0,0011	146,40	771,3
2	9.880.225	917.798	173.508	744.29	820.835	96.963	0,0006	86,20	778,8
3	1.976.045	150.601	26.985	123.616	130.117	20.484	0,0004	80,05	779,0
4	12.233.302	2.970.036	391.454	2.578.582	2.410.729	559.307	0,0011	146,40	771,3
5	2.445.060	565.855	47.735	518.12	489.248	76.607	0,0008	148,65	771,0

C	P	PG	PL	P1	PX	
1	17,6%	14,5%	85,5%	14,6%	3,0%	2004 R./2004 Inc.
2	9,3%	18,9%	81,1%	8,3%	1,0%	1980 R./2004 Inc.
3	7,6%	17,9%	82,1%	6,6%	1,0%	1980 R./1980 Inc.
4	24,3%	13,2%	86,8%	19,7%	4,6%	1980 Ext. R/2004 Inc.
5	23,1%	8,4%	91,6%	20,0%	3,1%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.185.100	665.904	511.429	154.475	580.148	85.756	0,0005	-46,25	771,3
2	2.788.500	171.785	150.756	21.029	159.602	12.183	0,0003	-14,75	771,3
3	557.7	26.998	26.985	13	25.579	1.419	0,0002	-7,15	771,5
4	4.396.600	494.119	360.673	133.446	420.546	73.573	0,0005	-46,25	771,3
5	878.8	49.606	47.735	1.871	30.996	18.61	0,0003	-29,70	771,0

C	P	PG	PL	P1	PX	
1	9,3%	76,8%	23,2%	8,1%	1,2%	2004 R./2004 Inc.
2	6,2%	87,8%	12,2%	5,7%	0,4%	1980 R./2004 Inc.
3	4,8%	100,0%	0,0%	4,6%	0,3%	1980 R./1980 Inc.
4	11,2%	73,0%	27,0%	9,6%	1,7%	1980 Ext. R/2004 Inc.
5	5,6%	96,2%	3,8%	3,5%	2,1%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.928.427	3.221.930	53.533	3.168.397	2.651.416	570.514	0,0011	146,40	771,3
2	7.091.725	746.013	22.752	723.261	661.233	84.78	0,0006	86,20	778,8
3	1.418.345	123.603	0	123.603	104.538	19.065	0,0004	80,05	779,0
4	7.836.702	2.475.917	30.781	2.445.136	1.990.183	485.734	0,0011	146,40	771,3
5	1.566.260	516.249	0	516.249	458.252	57.997	0,0008	148,65	771,0

C	P	PG	PL	P1	PX	
1	21,6%	1,7%	98,3%	17,8%	3,8%	2004 R./2004 Inc.
2	10,5%	3,0%	97,0%	9,3%	1,2%	1980 R./2004 Inc.
3	8,7%	0,0%	100,0%	7,4%	1,3%	1980 R./1980 Inc.
4	31,6%	1,2%	98,8%	25,4%	6,2%	1980 Ext. R/2004 Inc.
5	33,0%	0,0%	100,0%	29,3%	3,7%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.113.527	17.509.065	3.528.993	13.980.072	6.522.704	10.986.361	0,00072	148,60	770,9
2	9.873.981	6.894.071	1.367.128	5.526.943	3.661.731	3.232.340	0,00036	88,95	779,0
3	9.873.981	6.894.071	1.367.128	5.526.943	3.661.731	3.232.340	0,00036	88,95	779,0
4	12.239.546	10.614.994	2.161.865	8.453.129	2.860.973	7.754.021	0,00072	148,60	770,9
5	12.239.546	10.614.994	2.161.865	8.453.129	2.860.973	7.754.021	0,00072	148,60	770,9

C	P	PG	PL	P1	PX	
1	79,2%	20,2%	79,8%	29,5%	49,7%	2004 R./2004 Inc.
2	69,8%	19,8%	80,2%	37,1%	32,7%	1980 R./2004 Inc.
3	69,8%	19,8%	80,2%	37,1%	32,7%	1980 R./1980 Inc.
4	86,7%	20,4%	79,6%	23,4%	63,4%	1980 Ext. R/2004 Inc.
5	86,7%	20,4%	79,6%	23,4%	63,4%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.185.100	6.486.033	3.528.993	2.957.040	1.399.429	5.086.604	0,00033	-47,35	770,9
2	2.785.860	2.515.236	1.367.128	1.148.108	541.614	1.973.622	0,00020	-16,55	771,5
3	2.785.860	2.515.236	1.367.128	1.148.108	541.614	1.973.622	0,00020	-16,55	771,5
4	4.399.240	3.970.797	2.161.865	1.808.932	857.815	3.112.982	0,00033	-47,35	770,9
5	4.399.240	3.970.797	2.161.865	1.808.932	857.815	3.112.982	0,00033	-47,35	770,9

C	P	PG	PL	P1	PX	
1	90,3%	54,4%	45,6%	19,5%	70,8%	2004 R./2004 Inc.
2	90,3%	54,4%	45,6%	19,4%	70,8%	1980 R./2004 Inc.
3	90,3%	54,4%	45,6%	19,4%	70,8%	1980 R./1980 Inc.
4	90,3%	54,4%	45,6%	19,5%	70,8%	1980 Ext. R/2004 Inc.
5	90,3%	54,4%	45,6%	19,5%	70,8%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.928.427	11.023.032	0	11.023.032	5.123.275	5.899.757	0,00072	148,60	770,9
2	7.088.121	4.378.835	0	4.378.835	3.120.117	1.258.718	0,00036	88,95	779,0
3	7.088.121	4.378.835	0	4.378.835	3.120.117	1.258.718	0,00036	88,95	779,0
4	7.840.306	6.644.197	0	6.644.197	2.003.158	4.641.039	0,00072	148,60	770,9
5	7.840.306	6.644.197	0	6.644.197	2.003.158	4.641.039	0,00072	149,95	771,5

C	P	PG	PL	P1	PX	
1	73,8%	0,0%	100,0%	34,3%	39,5%	2004 R./2004 Inc.
2	61,8%	0,0%	100,0%	44,0%	17,8%	1980 R./2004 Inc.
3	61,8%	0,0%	100,0%	44,0%	17,8%	1980 R./1980 Inc.
4	84,7%	0,0%	100,0%	25,5%	59,2%	1980 Ext. R/2004 Inc.
5	84,7%	0,0%	100,0%	25,5%	59,2%	1980 Ext./1980 Inc.

VCF - 4 decimals

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.113.527	3.601.711	376.47	3.225.241	3.116.627	485.084	0,0008	148,10	770,9
2	9.873.981	763.678	135.889	627.789	660.743	102.935	0,0004	79,20	779,9
3	9.873.981	763.678	135.889	627.789	660.743	102.935	0,0004	79,20	779,9
4	12.239.546	2.838.033	240.581	2.597.452	2.455.884	382.149	0,0008	148,10	770,9
5	12.239.546	2.838.033	240.581	2.597.452	2.455.884	382.149	0,0008	148,10	770,9

C	P	PG	PL	P1	PX		
1	16,3%	10,5%	89,5%	14,1%	2,2%	2004 R./2004 Inc.	
2	7,7%	17,8%	82,2%	6,7%	1,0%	1980 R./2004 Inc.	
3	7,7%	17,8%	82,2%	6,7%	1,0%	1980 R./1980 Inc.	
4	23,2%	8,5%	91,5%	20,1%	3,1%	1980 Ext. R/2004 Inc.	
5	23,2%	8,5%	91,5%	20,1%	3,1%	1980 Ext./1980 Inc.	

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.185.100	385.221	376.47	8.751	285.461	99.76	0,0003	-29,25	771,2
2	2.785.860	135.936	135.889	47	129.148	6.788	0,0002	-6,95	771,8
3	2.785.860	135.936	135.889	47	129.148	6.788	0,0002	-6,95	771,8
4	4.399.240	249.285	240.581	8.704	156.313	92.972	0,0003	-29,25	771,2
5	4.399.240	249.285	240.581	8.704	156.313	92.972	0,0003	-29,25	771,2

C	P	PG	PL	P1	PX		
1	5,4%	97,7%	2,3%	4,0%	1,4%	2004 R./2004 Inc.	
2	4,9%	100,0%	0,0%	4,6%	0,2%	1980 R./2004 Inc.	
3	4,9%	100,0%	0,0%	4,6%	0,2%	1980 R./1980 Inc.	
4	5,7%	96,5%	3,5%	3,6%	2,1%	1980 Ext. R/2004 Inc.	
5	5,7%	96,5%	3,5%	3,6%	2,1%	1980 Ext./1980 Inc.	

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.928.427	3.216.490	0	3.216.490	2.831.166	385.324	0,0008	148,10	770,9
2	7.088.121	627.742	0	627.742	531.595	96.147	0,0004	79,20	779,9
3	7.088.121	627.742	0	627.742	531.595	96.147	0,0004	79,20	779,9
4	7.840.306	2.588.748	0	2.588.748	2.299.571	289.177	0,0008	148,10	770,9
5	7.840.306	2.588.748	0	2.588.748	2.299.571	289.177	0,0008	148,65	771,0

C	P	PG	PL	P1	PX		
1	21,5%	0,0%	100,0%	19,0%	2,6%	2004 R./2004 Inc.	
2	8,9%	0,0%	100,0%	7,5%	1,4%	1980 R./2004 Inc.	
3	8,9%	0,0%	100,0%	7,5%	1,4%	1980 R./1980 Inc.	
4	33,0%	0,0%	100,0%	29,3%	3,7%	1980 Ext. R/2004 Inc.	
5	33,0%	0,0%	100,0%	29,3%	3,7%	1980 Ext./1980 Inc.	



## 1.23. Table 54D – lubricants, 15 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 15 °C:** 801,3 kg/m<sup>3</sup> to 1.163,9 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	9.230.966	3.292.160	5.938.806	4.613.574	4.617.392	0,00007	-39,25	804,7
2	12.332.026	7.272.992	2.330.937	4.942.055	4.178.474	3.094.518	0,00006	-6,70	814,2
3	2.465.725	1.232.330	230.042	1.002.288	848.006	384.324	0,00005	14,90	1.142,0
4	2.175.600	1.957.974	961.223	996.751	435.1	1.522.874	0,00007	-39,25	804,7
5	435	391.596	192.215	199.381	87.153	304.443	0,00006	-39,45	823,5

C	P	PG	PL	P1	PX	
1	63,6%	35,7%	64,3%	31,8%	31,8%	2004 R./2004 Inc.
2	59,0%	32,0%	68,0%	33,9%	25,1%	1980 R./2004 Inc.
3	50,0%	18,7%	81,3%	34,4%	15,6%	1980 R./1980 Inc.
4	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.713.800	4.242.882	2.108.026	2.134.856	942.214	3.300.668	0,00007	-39,25	804,7
2	2.538.200	2.284.908	1.146.803	1.138.105	507.114	1.777.794	0,00006	-6,70	814,2
3	507.5	456.831	229.225	227.606	101.412	355.419	0,00005	14,90	1.142,0
4	2.175.600	1.957.974	961.223	996.751	435.1	1.522.874	0,00007	-39,25	804,7
5	435	391.596	192.215	199.381	87.153	304.443	0,00006	-39,45	823,5

C	P	PG	PL	P1	PX	
1	90,0%	49,7%	50,3%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	50,2%	49,8%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	50,2%	49,8%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.793.826	4.988.084	1.184.134	3.803.950	3.671.360	1.316.724	0,00005	143,95	803,8
2	9.793.826	4.988.084	1.184.134	3.803.950	3.671.360	1.316.724	0,00005	143,95	803,8
3	1.958.225	775.499	817	774.682	746.594	28.905	0,00002	102,35	971,0
4	0	0	0	0	0	0	0,00000	0,00	0,0
5	0	0	0	0	0	0	0,00000	0,00	0,0

C	P	PG	PL	P1	PX	
1	50,9%	23,7%	76,3%	37,5%	13,4%	2004 R./2004 Inc.
2	50,9%	23,7%	76,3%	37,5%	13,4%	1980 R./2004 Inc.
3	39,6%	0,1%	99,9%	38,1%	1,5%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	628.256	125.072	503.184	628.256	0	0,0001	14,80	837,1
2	12.332.026	535.179	87.436	447.743	535.179	0	0,0001	14,80	837,1
3	2.465.725	42.955	1.604	41.351	42.955	0	0,0001	14,40	837,0
4	2.175.600	93.077	37.636	55.441	93.077	0	0,0001	-20,05	803,3
5	435	7.009	1.703	5.306	7.009	0	0,0001	-20,05	812,5

C	P	PG	PL	P1	PX	
1	4,3%	19,9%	80,1%	4,3%	0,0%	2004 R./2004 Inc.
2	4,3%	16,3%	83,7%	4,3%	0,0%	1980 R./2004 Inc.
3	1,7%	3,7%	96,3%	1,7%	0,0%	1980 R./1980 Inc.
4	4,3%	40,4%	59,6%	4,3%	0,0%	1980 Ext. R/2004 Inc.
5	1,6%	24,3%	75,7%	1,6%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.713.800	131.436	58.789	72.647	131.436	0	0,0001	14,80	837,1
2	2.538.200	38.359	21.153	17.206	38.359	0	0,0001	14,80	837,1
3	507.5	2.473	1.604	869	2.473	0	0,0001	14,40	837,0
4	2.175.600	93.077	37.636	55.441	93.077	0	0,0001	-20,05	803,3
5	435	7.009	1.703	5.306	7.009	0	0,0001	-20,05	812,5

C	P	PG	PL	P1	PX	
1	2,8%	44,7%	55,3%	2,8%	0,0%	2004 R./2004 Inc.
2	1,5%	55,1%	44,9%	1,5%	0,0%	1980 R./2004 Inc.
3	0,5%	64,9%	35,1%	0,5%	0,0%	1980 R./1980 Inc.
4	4,3%	40,4%	59,6%	4,3%	0,0%	1980 Ext. R/2004 Inc.
5	1,6%	24,3%	75,7%	1,6%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.793.826	496.82	66.283	9.793.826	496.82	0	0,0001	35,40	821,8
2	9.793.826	496.82	66.283	430.537	496.82	0	0,0001	35,40	821,8
3	1.958.225	40.482	0	40.482	40.482	0	0,0001	62,50	1115,0
4	0	0	0	0	0	0	0,0000	0,00	0,0
5	0	0	0	0	0	0	0,0000	0,00	0,0

C	P	PG	PL	P1	PX	
1	5,1%	13,3%	86,7%	5,1%	0,0%	2004 R./2004 Inc.
2	5,1%	13,3%	86,7%	5,1%	0,0%	1980 R./2004 Inc.
3	2,1%	0,0%	100,0%	2,1%	0,0%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	8.152.218	2.112.330	6.039.888	4.695.560	3.456.658	0,00006	-34,75	804,2
2	12.332.026	6.194.244	1.150.991	5.043.253	4.260.460	1.933.784	0,00005	14,90	1.141,6
3	12.332.026	6.194.244	1.150.991	5.043.253	4.260.460	1.933.784	0,00005	14,90	1.141,6
4	2.175.600	1.957.974	961.339	996.635	435.1	1.522.874	0,00006	-34,75	804,2
5	2.175.600	1.957.974	961.339	996.635	435.1	1.522.874	0,00006	-34,75	804,2

C	P	PG	PL	P1	PX	
1	56,2%	25,9%	74,1%	32,4%	23,8%	2004 R./2004 Inc.
2	50,2%	18,6%	81,4%	34,5%	15,7%	1980 R./2004 Inc.
3	50,2%	18,6%	81,4%	34,5%	15,7%	1980 R./1980 Inc.
4	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.713.800	4.242.882	2.108.537	2.134.345	942.214	3.300.668	0,00006	-34,75	804,2
2	2.538.200	2.284.908	1.147.198	1.137.710	507.114	1.777.794	0,00005	14,90	1.141,6
3	2.538.200	2.284.908	1.147.198	1.137.710	507.114	1.777.794	0,00005	14,90	1.141,6
4	2.175.600	1.957.974	961.339	996.635	435.1	1.522.874	0,00006	-34,75	804,2
5	2.175.600	1.957.974	961.339	996.635	435.1	1.522.874	0,00006	-34,75	804,2

C	P	PG	PL	P1	PX	
1	90,0%	49,7%	50,3%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	50,2%	49,8%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	50,2%	49,8%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	49,1%	50,9%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.793.826	3.909.336	3.793	3.905.543	3.753.346	155.99	0,00002	101,40	1151,4
2	9.793.826	3.909.336	3.793	3.905.543	3.753.346	155.99	0,00002	101,40	1151,4
3	9.793.826	3.909.336	3.793	3.905.543	3.753.346	155.99	0,00002	101,40	1151,4
4	0	0	0	0	0	0	0,00000	0,00	0,0
5	0	0	0	0	0	0	0,00000	0,00	0,0

C	P	PG	PL	P1	PX	
1	39,9%	0,1%	99,9%	38,3%	1,6%	2004 R./2004 Inc.
2	39,9%	0,1%	99,9%	38,3%	1,6%	1980 R./2004 Inc.
3	39,9%	0,1%	99,9%	38,3%	1,6%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	256.638	17.438	239.2	256.638	0	0,0001	14,75	1.046,3
2	12.332.026	221.213	8.57	212.643	221.213	0	0,0001	14,75	1.046,3
3	12.332.026	221.213	8.57	212.643	221.213	0	0,0001	14,75	1.046,3
4	2.175.600	35.425	8.868	26.557	35.425	0	0,0001	-20,05	803,4
5	2.175.600	35.425	8.868	26.557	35.425	0	0,0001	-20,05	803,4

C	P	PG	PL	P1	PX				
1	1,8%	6,8%	93,2%	1,8%	0,0%				2004 R./2004 Inc.
2	1,8%	3,9%	96,1%	1,8%	0,0%				1980 R./2004 Inc.
3	1,8%	3,9%	96,1%	1,8%	0,0%				1980 R./1980 Inc.
4	1,6%	25,0%	75,0%	1,6%	0,0%				1980 Ext. R/2004 Inc.
5	1,6%	25,0%	75,0%	1,6%	0,0%				1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	4.713.800	48.223	17.438	30.785	48.223	0	0,0001	14,75	1.046,3
2	2.538.200	12.798	8.57	4.228	12.798	0	0,0001	14,75	1.046,3
3	2.538.200	12.798	8.57	4.228	12.798	0	0,0001	14,75	1.046,3
4	2.175.600	35.425	8.868	26.557	35.425	0	0,0001	-20,05	803,4
5	2.175.600	35.425	8.868	26.557	35.425	0	0,0001	-20,05	803,4

C	P	PG	PL	P1	PX				
1	1,0%	36,2%	63,8%	1,0%	0,0%				2004 R./2004 Inc.
2	0,5%	67,0%	33,0%	0,5%	0,0%				1980 R./2004 Inc.
3	0,5%	67,0%	33,0%	0,5%	0,0%				1980 R./1980 Inc.
4	1,6%	25,0%	75,0%	1,6%	0,0%				1980 Ext. R/2004 Inc.
5	1,6%	25,0%	75,0%	1,6%	0,0%				1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.793.826	208.415	0	208.415	0	0,0001	61,70	1151,4	208.415
2	9.793.826	208.415	0	208.415	0	0,0001	61,70	1151,4	208.415
3	9.793.826	208.415	0	208.415	0	0,0001	61,70	1151,4	208.415
4	0	0	0	0	0	0,0000	0,00	0,0	0
5	0	0	0	0	0	0,0000	0,00	0,0	0

C	P	PG	PL	P1	PX				
1	2,1%	0,0%	100,0%	2,1%	0,0%				2004 R./2004 Inc.
2	2,1%	0,0%	100,0%	2,1%	0,0%				1980 R./2004 Inc.
3	2,1%	0,0%	100,0%	2,1%	0,0%				1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%				1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%				1980 Ext./1980 Inc.



## 1.24. Table 60A – crude oil, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 20 °C:** 606,1 kg/m<sup>3</sup> to 1.161,2 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.205.550	18.331.197	4.501.549	13.829.648	4.663.714	13.667.483	0,00039	148,60	616,3
2	8.268.785	6.304.790	1.295.656	5.009.134	2.130.824	4.173.966	0,00011	115,50	834,8
3	1.653.757	1.403.076	245.777	1.157.299	471.641	931.435	0,00007	-6,20	754,5
4	13.936.765	12.026.407	3.205.893	8.820.514	2.532.890	9.493.517	0,00039	148,60	616,3
5	2.787.353	2.544.391	628.776	1.915.615	470.783	2.073.608	0,00025	148,20	616,5

C	P	PG	PL	P1	PX	
1	82,6%	24,6%	75,4%	21,0%	61,5%	2004 R./2004 Inc.
2	76,2%	20,6%	79,4%	25,8%	50,5%	1980 R./2004 Inc.
3	84,8%	17,5%	82,5%	28,5%	56,3%	1980 R./1980 Inc.
4	86,3%	26,7%	73,3%	18,2%	68,1%	1980 Ext. R/2004 Inc.
5	91,3%	24,7%	75,3%	16,9%	74,4%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.770.000	7.021.292	4.343.841	2.677.451	1.487.860	5.533.432	0,00016	-42,10	616,3
2	2.420.600	2.178.693	1.228.498	950.195	483.989	1.694.704	0,00009	-11,55	754,8
3	484.12	435.826	245.777	190.049	96.939	338.887	0,00007	-6,20	754,5
4	5.349.400	4.842.599	3.115.343	1.727.256	1.003.871	3.838.728	0,00016	-42,10	616,3
5	1.069.880	962.927	628.776	334.151	212.992	749.935	0,00010	-33,50	616,5

C	P	PG	PL	P1	PX	
1	90,4%	61,9%	38,1%	19,1%	71,2%	2004 R./2004 Inc.
2	90,0%	56,4%	43,6%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	56,4%	43,6%	20,0%	70,0%	1980 R./1980 Inc.
4	90,5%	64,3%	35,7%	18,8%	71,8%	1980 Ext. R/2004 Inc.
5	90,0%	65,3%	34,7%	19,9%	70,1%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.435.550	11.309.905	157.708	11.152.197	3.175.854	8.134.051	0,00039	148,60	616,3
2	5.848.185	4.126.097	67.158	4.058.939	1.646.835	2.479.262	0,00011	115,50	834,8
3	1.169.637	967.25	0	967.25	374.702	592.548	0,00007	117,15	838,0
4	8.587.365	7.183.808	90.55	7.093.258	1.529.019	5.654.789	0,00039	148,60	616,3
5	1.717.473	1.581.464	0	1.581.464	257.791	1.323.673	0,00025	148,20	616,5

C	P	PG	PL	P1	PX	
1	78,3%	1,4%	98,6%	22,0%	56,3%	2004 R./2004 Inc.
2	70,6%	1,6%	98,4%	28,2%	42,4%	1980 R./2004 Inc.
3	82,7%	0,0%	100,0%	32,0%	50,7%	1980 R./1980 Inc.
4	83,7%	1,3%	98,7%	17,8%	65,9%	1980 Ext. R/2004 Inc.
5	92,1%	0,0%	100,0%	15,0%	77,1%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.205.550	5.280.451	936.264	4.344.187	4.723.798	556.653	0,0004	124,50	615,3
2	8.268.785	1.078.882	143.403	935.479	1.078.876	6	0,0002	116,90	837,8
3	1.653.757	213.585	27.682	185.903	213.585	0	0,0001	19,75	1.011,0
4	13.936.765	4.201.569	792.861	3.408.708	3.644.922	556.647	0,0004	124,50	615,3
5	2.787.353	880.773	147.403	733.37	815.142	65.631	0,0003	129,90	616,5

C	P	PG	PL	P1	PX	
1	23,8%	17,7%	82,3%	21,3%	2,5%	2004 R./2004 Inc.
2	13,0%	13,3%	86,7%	13,0%	0,0%	1980 R./2004 Inc.
3	12,9%	13,0%	87,0%	12,9%	0,0%	1980 R./1980 Inc.
4	30,1%	18,9%	81,1%	26,2%	4,0%	1980 Ext. R/2004 Inc.
5	31,6%	16,7%	83,3%	29,2%	2,4%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.770.000	993.07	934.153	58.917	992.92	150	0,0002	-36,90	615,3
2	2.420.600	147.34	143.012	4.328	147.34	0	0,0001	19,95	782,8
3	484.12	27.682	27.682	0	27.682	0	0,0001	19,75	1.011,0
4	5.349.400	845.73	791.141	54.589	845.58	150	0,0002	-36,90	615,3
5	1.069.880	147.403	147.403	0	147.403	0	0,0001	19,80	700,0

C	P	PG	PL	P1	PX	
1	12,8%	94,1%	5,9%	12,8%	0,0%	2004 R./2004 Inc.
2	6,1%	97,1%	2,9%	6,1%	0,0%	1980 R./2004 Inc.
3	5,7%	100,0%	0,0%	5,7%	0,0%	1980 R./1980 Inc.
4	15,8%	93,5%	6,5%	15,8%	0,0%	1980 Ext. R/2004 Inc.
5	13,8%	100,0%	0,0%	13,8%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.435.550	4.287.381	2.111	4.285.270	3.730.878	556.503	0,0004	124,50	615,3
2	5.848.185	931.542	391	931.151	931.536	6	0,0002	116,90	837,8
3	1.169.637	185.903	0	185.903	185.903	0	0,0001	27,45	754,0
4	8.587.365	3.355.839	1.72	3.354.119	2.799.342	556.497	0,0004	124,50	615,3
5	1.717.473	733.37	0	733.37	667.739	65.631	0,0003	129,90	616,5

C	P	PG	PL	P1	PX	
1	29,7%	0,0%	100,0%	25,8%	3,9%	2004 R./2004 Inc.
2	15,9%	0,0%	100,0%	15,9%	0,0%	1980 R./2004 Inc.
3	15,9%	0,0%	100,0%	15,9%	0,0%	1980 R./1980 Inc.
4	39,1%	0,1%	99,9%	32,6%	6,5%	1980 Ext. R/2004 Inc.
5	42,7%	0,0%	100,0%	38,9%	3,8%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.205.550	19.739.168	4.371.309	15.367.859	4.706.378	15.032.790	0,00025	147,45	616,3
2	8.264.463	7.011.349	1.226.979	5.784.370	2.355.651	4.655.698	0,00007	-4,85	754,1
3	8.264.463	7.011.349	1.226.979	5.784.370	2.355.651	4.655.698	0,00007	-4,85	754,1
4	13.941.087	12.727.819	3.144.330	9.583.489	2.350.727	10.377.092	0,00025	147,45	616,3
5	13.941.087	12.727.819	3.144.330	9.583.489	2.350.727	10.377.092	0,00025	147,45	616,3

C	P	PG	PL	P1	PX	
1	88,9%	22,1%	77,9%	21,2%	67,7%	2004 R./2004 Inc.
2	84,8%	17,5%	82,5%	28,5%	56,3%	1980 R./2004 Inc.
3	84,8%	17,5%	82,5%	28,5%	56,3%	1980 R./1980 Inc.
4	91,3%	24,7%	75,3%	16,9%	74,4%	1980 Ext. R/2004 Inc.
5	91,3%	24,7%	75,3%	16,9%	74,4%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.770.000	6.993.758	4.371.309	2.622.449	1.548.771	5.444.987	0,00010	-31,50	616,4
2	2.419.080	2.177.317	1.226.979	950.338	483.709	1.693.608	0,00007	-4,85	754,1
3	2.419.080	2.177.317	1.226.979	950.338	483.709	1.693.608	0,00007	-4,85	754,1
4	5.350.920	4.816.441	3.144.330	1.672.111	1.065.062	3.751.379	0,00010	-31,50	616,4
5	5.350.920	4.816.441	3.144.330	1.672.111	1.065.062	3.751.379	0,00010	-31,50	616,4

C	P	PG	PL	P1	PX	
1	90,0%	62,5%	37,5%	19,9%	70,1%	2004 R./2004 Inc.
2	90,0%	56,4%	43,6%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	56,4%	43,6%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	65,3%	34,7%	19,9%	70,1%	1980 Ext. R/2004 Inc.
5	90,0%	65,3%	34,7%	19,9%	70,1%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.435.550	12.745.410	0	12.745.410	3.157.607	9.587.803	0,00025	147,45	616,3
2	5.845.383	4.834.032	0	4.834.032	1.871.942	2.962.090	0,00007	114,45	837,7
3	5.845.383	4.834.032	0	4.834.032	1.871.942	2.962.090	0,00007	114,45	837,7
4	8.590.167	7.911.378	0	7.911.378	1.285.665	6.625.713	0,00025	147,45	616,3
5	8.590.167	7.911.378	0	7.911.378	1.285.665	6.625.713	0,00025	148,20	616,5

C	P	PG	PL	P1	PX	
1	88,3%	0,0%	100,0%	21,9%	66,4%	2004 R./2004 Inc.
2	82,7%	0,0%	100,0%	32,0%	50,7%	1980 R./2004 Inc.
3	82,7%	0,0%	100,0%	32,0%	50,7%	1980 R./1980 Inc.
4	92,1%	0,0%	100,0%	15,0%	77,1%	1980 Ext. R/2004 Inc.
5	92,1%	0,0%	100,0%	15,0%	77,1%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.205.550	5.467.417	874.058	4.593.359	5.136.439	330.978	0,0003	128,70	616,3
2	8.264.463	1.063.452	137.849	925.603	1.063.452	0	0,0001	19,95	782,8
3	8.264.463	1.063.452	137.849	925.603	1.063.452	0	0,0001	19,95	782,8
4	13.941.087	4.403.965	736.209	3.667.756	4.072.987	330.978	0,0003	128,70	616,3
5	13.941.087	4.403.965	736.209	3.667.756	4.072.987	330.978	0,0003	128,70	616,3

C	P	PG	PL	P1	PX	
1	24,6%	16,0%	84,0%	23,1%	1,5%	2004 R./2004 Inc.
2	12,9%	13,0%	87,0%	12,9%	0,0%	1980 R./2004 Inc.
3	12,9%	13,0%	87,0%	12,9%	0,0%	1980 R./1980 Inc.
4	31,6%	16,7%	83,3%	29,2%	2,4%	1980 Ext. R/2004 Inc.
5	31,6%	16,7%	83,3%	29,2%	2,4%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.770.000	874.058	874.058	0	874.058	0	0,0001	19,95	782,8
2	2.419.080	137.849	137.849	0	137.849	0	0,0001	19,95	782,8
3	2.419.080	137.849	137.849	0	137.849	0	0,0001	19,95	782,8
4	5.350.920	736.209	736.209	0	736.209	0	0,0001	19,90	638,8
5	5.350.920	736.209	736.209	0	736.209	0	0,0001	19,90	638,8

C	P	PG	PL	P1	PX	
1	11,2%	100,0%	0,0%	11,2%	0,0%	2004 R./2004 Inc.
2	5,7%	100,0%	0,0%	5,7%	0,0%	1980 R./2004 Inc.
3	5,7%	100,0%	0,0%	5,7%	0,0%	1980 R./1980 Inc.
4	13,8%	100,0%	0,0%	13,8%	0,0%	1980 Ext. R/2004 Inc.
5	13,8%	100,0%	0,0%	13,8%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.435.550	4.593.359	0	4.593.359	4.262.381	330.978	0,0003	128,70	616,3
2	5.845.383	925.603	0	925.603	925.603	0	0,0001	27,45	754,0
3	5.845.383	925.603	0	925.603	925.603	0	0,0001	27,45	754,0
4	8.590.167	3.667.756	0	3.667.756	3.336.778	330.978	0,0003	128,70	616,3
5	8.590.167	3.667.756	0	3.667.756	3.336.778	330.978	0,0003	129,90	616,5

C	P	PG	PL	P1	PX	
1	31,8%	0,0%	100,0%	29,5%	2,3%	2004 R./2004 Inc.
2	15,8%	0,0%	100,0%	15,8%	0,0%	1980 R./2004 Inc.
3	15,8%	0,0%	100,0%	15,8%	0,0%	1980 R./1980 Inc.
4	42,7%	0,0%	0,0%	38,8%	3,9%	1980 Ext. R/2004 Inc.
5	42,7%	0,0%	0,0%	38,8%	3,9%	1980 Ext./1980 Inc.



## 1.25. Table 60B – products, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 20 °C:** 611,2 kg/m<sup>3</sup> to 1.160,6 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.185.545	16.920.807	4.948.001	11.972.806	5.549.683	11.371.124	0,00105	149,90	768,3
2	9.904.835	6.802.504	2.119.471	4.683.033	2.876.496	3.926.008	0,00052	89,10	776,3
3	1.980.967	1.375.950	320.456	1.055.494	697.496	678.454	0,00036	88,45	776,5
4	12.280.710	10.118.303	2.828.530	7.289.773	2.673.187	7.445.116	0,00105	149,90	768,3
5	2.456.142	2.124.916	454.327	1.670.589	568.955	1.555.961	0,00074	149,25	768,5

C	P	PG	PL	P1	PX	
1	76,3%	29,2%	70,8%	25,0%	51,3%	2004 R./2004 Inc.
2	68,7%	31,2%	68,8%	29,0%	39,6%	1980 R./2004 Inc.
3	69,5%	23,3%	76,7%	35,2%	34,2%	1980 R./1980 Inc.
4	82,4%	28,0%	72,0%	21,8%	60,6%	1980 Ext. R/2004 Inc.
5	86,5%	21,4%	78,6%	23,2%	63,3%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.763.000	7.010.582	3.871.143	3.139.439	1.497.423	5.513.159	0,00053	-49,90	768,3
2	3.218.600	2.905.870	1.599.234	1.306.636	625.861	2.280.009	0,00032	-17,95	768,3
3	643.72	581.389	320.45	260.939	125.091	456.298	0,00024	-17,95	768,5
4	4.544.400	4.104.712	2.271.909	1.832.803	871.562	3.233.150	0,00053	-49,90	768,3
5	908.88	820.374	454.327	366.047	177.313	643.061	0,00038	-49,90	768,5

C	P	PG	PL	P1	PX	
1	90,3%	55,2%	44,8%	19,3%	71,0%	2004 R./2004 Inc.
2	90,3%	55,0%	45,0%	19,4%	70,8%	1980 R./2004 Inc.
3	90,3%	55,1%	44,9%	19,4%	70,9%	1980 R./1980 Inc.
4	90,3%	55,3%	44,7%	19,2%	71,1%	1980 Ext. R/2004 Inc.
5	90,3%	55,4%	44,6%	19,5%	70,8%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.422.545	9.910.225	1.076.858	8.833.367	4.052.260	5.857.965	0,00105	149,90	768,3
2	6.686.235	3.896.634	520.237	3.376.397	2.250.635	1.645.999	0,00052	89,10	776,3
3	1.337.247	794.561	6	794.555	572.405	222.156	0,00036	88,45	776,5
4	7.736.310	6.013.591	556.621	5.456.970	1.801.625	4.211.966	0,00105	149,90	768,3
5	1.547.262	1.304.542	0	1.304.542	391.642	912.9	0,00074	149,25	768,5

C	P	PG	PL	P1	PX	
1	68,7%	10,9%	89,1%	28,1%	40,6%	2004 R./2004 Inc.
2	58,3%	13,4%	86,6%	33,7%	24,6%	1980 R./2004 Inc.
3	59,4%	0,0%	100,0%	42,8%	16,6%	1980 R./1980 Inc.
4	77,7%	9,3%	90,7%	23,3%	54,4%	1980 Ext. R/2004 Inc.
5	84,3%	0,0%	100,0%	25,3%	59,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.185.545	3.934.610	684.845	3.249.765	3.288.632	645.978	0,0011	145,10	768,3
2	9.904.835	915.411	226.896	688.515	821.631	93.78	0,0006	88,20	776,3
3	1.980.967	150.535	36.764	113.771	131.443	19.092	0,0004	79,65	776,5
4	12.280.710	3.019.199	457.949	2.561.250	2.467.001	552.198	0,0011	145,10	768,3
5	2.456.142	568.475	58.841	509.634	488.036	80.439	0,0008	145,10	768,5

C	P	PG	PL	P1	PX	
1	17,7%	17,4%	82,6%	14,8%	2,9%	2004 R./2004 Inc.
2	9,2%	24,8%	75,2%	8,3%	0,9%	1980 R./2004 Inc.
3	7,6%	24,4%	75,6%	6,6%	1,0%	1980 R./1980 Inc.
4	24,6%	15,2%	84,8%	20,1%	4,5%	1980 Ext. R/2004 Inc.
5	23,1%	10,4%	89,6%	19,9%	3,3%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.763.000	791.57	622.226	169.344	688.983	102.587	0,0005	-38,00	768,3
2	3.218.600	230.429	203.933	26.496	209.846	20.583	0,0003	-7,65	768,3
3	643.72	36.902	36.764	138	33.857	3.045	0,0002	-0,65	768,5
4	4.544.400	561.141	418.293	142.848	479.137	82.004	0,0005	-38,00	768,3
5	908.88	62.089	58.841	3.248	41.58	20.509	0,0004	-44,30	768,5

C	P	PG	PL	P1	PX	
1	10,2%	78,6%	21,4%	8,9%	1,3%	2004 R./2004 Inc.
2	7,2%	88,5%	11,5%	6,5%	0,6%	1980 R./2004 Inc.
3	5,7%	99,6%	0,4%	5,3%	0,5%	1980 R./1980 Inc.
4	12,3%	74,5%	25,5%	10,5%	1,8%	1980 Ext. R/2004 Inc.
5	6,8%	94,8%	5,2%	4,6%	2,3%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.422.545	3.143.040	62.619	3.080.421	2.599.649	543.391	0,0011	145,10	768,3
2	6.686.235	684.982	22.963	662.019	611.785	73.197	0,0006	88,20	776,3
3	1.337.247	113.633	0	113.633	97.586	16.047	0,0004	79,65	776,5
4	7.736.310	2.458.058	39.656	2.418.402	1.987.864	470.194	0,0011	145,10	768,3
5	1.547.262	506.386	0	506.386	446.456	59.93	0,0008	145,10	768,5

C	P	PG	PL	P1	PX	
1	21,8%	2,0%	98,0%	18,0%	3,8%	2004 R./2004 Inc.
2	10,2%	3,4%	96,6%	9,1%	1,1%	1980 R./2004 Inc.
3	8,5%	0,0%	100,0%	7,3%	1,2%	1980 R./1980 Inc.
4	31,8%	1,6%	98,4%	25,7%	6,1%	1980 Ext. R/2004 Inc.
5	32,7%	0,0%	100,0%	28,9%	3,9%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.185.545	17.535.893	3.872.586	13.663.307	6.343.805	11.192.088	0,00074	149,25	768,5
2	9.905.557	6.872.039	1.601.381	5.270.658	3.473.464	3.398.575	0,00036	88,45	776,5
3	9.905.557	6.872.039	1.601.381	5.270.658	3.473.464	3.398.575	0,00036	88,45	776,5
4	12.279.988	10.663.854	2.271.205	8.392.649	2.870.341	7.793.513	0,00074	149,25	768,5
5	12.279.988	10.663.854	2.271.205	8.392.649	2.870.341	7.793.513	0,00074	149,25	768,5

C	P	PG	PL	P1	PX	
1	79,0%	22,1%	77,9%	28,6%	50,4%	2004 R./2004 Inc.
2	69,4%	23,3%	76,7%	35,1%	34,3%	1980 R./2004 Inc.
3	69,4%	23,3%	76,7%	35,1%	34,3%	1980 R./1980 Inc.
4	86,8%	21,3%	78,7%	23,4%	63,5%	1980 Ext. R/2004 Inc.
5	86,8%	21,3%	78,7%	23,4%	63,5%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.763.000	7.008.503	3.872.561	3.135.942	1.510.040	5.498.463	0,00038	-49,85	768,3
2	3.220.120	2.908.096	1.601.358	1.306.738	624.609	2.283.487	0,00024	-17,95	768,5
3	3.220.120	2.908.096	1.601.358	1.306.738	624.609	2.283.487	0,00024	-17,95	768,5
4	4.542.880	4.100.407	2.271.203	1.829.204	885.431	3.214.976	0,00038	-49,85	768,3
5	4.542.880	4.100.407	2.271.203	1.829.204	885.431	3.214.976	0,00038	-49,85	768,3

C	P	PG	PL	P1	PX	
1	90,3%	55,3%	44,7%	19,5%	70,8%	2004 R./2004 Inc.
2	90,3%	55,1%	44,9%	19,4%	70,9%	1980 R./2004 Inc.
3	90,3%	55,1%	44,9%	19,4%	70,9%	1980 R./1980 Inc.
4	90,3%	55,4%	44,6%	19,5%	70,8%	1980 Ext. R/2004 Inc.
5	90,3%	55,4%	44,6%	19,5%	70,8%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.422.545	10.527.390	25	10.527.365	4.833.765	5.693.625	0,00074	149,25	768,5
2	6.685.437	3.963.943	23	3.963.920	2.848.855	1.115.088	0,00036	88,45	776,5
3	6.685.437	3.963.943	23	3.963.920	2.848.855	1.115.088	0,00036	88,45	776,5
4	7.737.108	6.563.447	2	6.563.445	1.984.910	4.578.537	0,00074	149,25	768,5
5	7.737.108	6.563.447	2	6.563.445	1.984.910	4.578.537	0,00074	149,25	768,5

C	P	PG	PL	P1	PX	
1	73,0%	0,0%	100,0%	33,5%	39,5%	2004 R./2004 Inc.
2	59,3%	0,0%	100,0%	42,6%	16,7%	1980 R./2004 Inc.
3	59,3%	0,0%	100,0%	42,6%	16,7%	1980 R./1980 Inc.
4	84,8%	0,0%	100,0%	25,7%	59,2%	1980 Ext. R/2004 Inc.
5	84,8%	0,0%	100,0%	25,7%	59,2%	1980 Ext./1980 Inc.

VCF - 4 decimals

#### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	22.185.54	3.593.04	478.31	3.114.73	3.095.08	497.962	0,0008	145,10	768,5
2	9.905.557	747.684	183.57	564.113	653.429	94.255	0,0004	79,65	776,5
3	9.905.557	747.684	183.57	564.113	653.429	94.255	0,0004	79,65	776,5
4	12.279.98	2.845.36	294.74	2.550.62	2.441.65	403.707	0,0008	145,10	768,5
5	12.279.98	2.845.36	294.74	2.550.62	2.441.65	403.707	0,0008	145,10	768,5

C	P	PG	PL	P1	PX	
1	16,2%	13,3%	86,7%	14,0%	2,2%	2004 R./2004 Inc.
2	7,5%	24,6%	75,4%	6,6%	1,0%	1980 R./2004 Inc.
3	7,5%	24,6%	75,4%	6,6%	1,0%	1980 R./1980 Inc.
4	23,2%	10,4%	89,6%	19,9%	3,3%	1980 Ext. R/2004 Inc.
5	23,2%	10,4%	89,6%	19,9%	3,3%	1980 Ext./1980 Inc.

#### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	7.763.000	494.951	478.31	16.644	377.197	117.754	0,0004	-43,80	768,3
2	3.220.120	184.248	183.57	677	169.462	14.786	0,0002	-0,25	768,3
3	3.220.120	184.248	183.57	677	169.462	14.786	0,0002	-0,25	768,3
4	4.542.880	310.703	294.74	15.967	207.735	102.968	0,0004	-43,80	768,3
5	4.542.880	310.703	294.74	15.967	207.735	102.968	0,0004	-43,80	768,3

C	P	PG	PL	P1	PX	
1	6,4%	96,6%	3,4%	4,9%	1,5%	2004 R./2004 Inc.
2	5,7%	99,6%	0,4%	5,3%	0,5%	1980 R./2004 Inc.
3	5,7%	99,6%	0,4%	5,3%	0,5%	1980 R./1980 Inc.
4	6,8%	94,9%	5,1%	4,6%	2,3%	1980 Ext. R/2004 Inc.
5	6,8%	94,9%	5,1%	4,6%	2,3%	1980 Ext./1980 Inc.

#### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.422.54	3.098.09	0	3.098.09	2.717.88	380.208	0,0008	145,10	768,5
2	6.685.437	563.436	0	563.436	483.967	79.469	0,0004	79,65	776,5
3	6.685.437	563.436	0	563.436	483.967	79.469	0,0004	79,65	776,5
4	7.737.108	2.534.65	0	2.534.65	2.233.91	300.739	0,0008	145,10	768,5
5	7.737.108	2.534.65	0	2.534.65	2.233.91	300.739	0,0008	145,10	768,5

C	P	PG	PL	P1	PX	
1	21,5%	0,0%	100,0%	18,8%	2,6%	2004 R./2004 Inc.
2	8,4%	0,0%	100,0%	7,2%	1,2%	1980 R./2004 Inc.
3	8,4%	0,0%	100,0%	7,2%	1,2%	1980 R./1980 Inc.
4	32,8%	0,0%	100,0%	28,9%	3,9%	1980 Ext. R/2004 Inc.
5	32,8%	0,0%	100,0%	28,9%	3,9%	1980 Ext./1980 Inc.



## 1.26. Table 60D – lubricants, 20 °C base temperature – detailed results

### Comparison grid:

**Observed temperature:** -50 °C to 150 °C, increment 0,05 °C

**Base density @ 20 °C:** 798,1 kg/m<sup>3</sup> to 1.160,7 kg/m<sup>3</sup>, increment 0,1 kg/m<sup>3</sup>

**Quantity compared:** Volume correction factor observed to base (5 & 4 decimals rounding)

### Absolute numbers:

**NSC:** Number of successful calculations (may be smaller than calculated grid points)

**NDF:** Number of deviations found

**NDG:** Number of deviations where 2004 result lies above 1980 result

**NDL:** Number of deviations where 2004 result lies below 1980 result

**NDI1:** Number of deviations which differ by one result grid rounding increment

**NDG1:** Number of deviations which differ by more than one result grid rounding increment

**MAXD:** Maximum deviation found

**TLCB:** Temperature value closest to base at which maximum deviation occurs

**DTLCB:** Density value for closest temperature value where maximum deviation occurs

### Calculated % ratios:

**P :** % value of differences:  $(NDF / NSC) * 100$

**PG:** % value of deviations - 2004 value above 1980 value:  $(NDG / NDF) * 100$

**PL:** % value of deviations - 2004 value below 1980 value:  $(NDL / NDF) * 100$

**P1:** % value of deviations - deviation one result grid increment:  $(NDI1 / NSC) * 100$

**PX:** % value of deviations - deviation above one result grid increment:  $(NDG1 / NSC) * 100$



Results ASTM D1250-80 standard rounding

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	9.182.819	3.793.338	5.389.481	4.646.056	4.536.763	0,00007	-30,05	807,2
2	12.332.026	7.224.670	2.860.553	4.364.117	4.210.849	3.013.821	0,00006	1,05	816,2
3	2.465.725	999.643	281.626	718.017	592.424	407.219	0,00005	19,90	1.143,5
4	2.175.600	1.958.149	932.785	1.025.364	435.207	1.522.942	0,00007	-30,05	807,2
5	435	391.675	186.595	205.08	87.327	304.348	0,00006	-25,30	809,0

C	P	PG	PL	P1	PX	
1	63,3%	41,3%	58,7%	32,0%	31,3%	2004 R./2004 Inc.
2	58,6%	39,6%	60,4%	34,1%	24,4%	1980 R./2004 Inc.
3	40,5%	28,2%	71,8%	24,0%	16,5%	1980 R./1980 Inc.
4	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	47,6%	52,4%	20,1%	70,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	5.076.400	4.569.602	2.231.352	2.338.250	1.015.165	3.554.437	0,00007	-30,05	807,2
2	2.900.800	2.611.453	1.298.567	1.312.886	579.958	2.031.495	0,00006	1,05	816,2
3	580	522.149	259.592	262.557	116.038	406.111	0,00005	19,90	1.143,5
4	2.175.600	1.958.149	932.785	1.025.364	435.207	1.522.942	0,00007	-30,05	807,2
5	435	391.675	186.595	205.08	87.327	304.348	0,00006	-25,30	809,0

C	P	PG	PL	P1	PX	
1	90,0%	48,8%	51,2%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	49,7%	50,3%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	49,7%	50,3%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	47,6%	52,4%	20,1%	70,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.431.226	4.613.217	1.561.986	3.051.231	3.630.891	982.326	0,00004	129,60	800,8
2	9.431.226	4.613.217	1.561.986	3.051.231	3.630.891	982.326	0,00004	129,60	800,8
3	1.885.725	477.494	22.034	455.46	476.386	1.108	0,00002	124,45	1133,5
4	0	0	0	0	0	0	0,00000	0,00	0,0
5	0	0	0	0	0	0	0,00000	0,00	0,0

C	P	PG	PL	P1	PX	
1	48,9%	33,9%	66,1%	38,5%	10,4%	2004 R./2004 Inc.
2	48,9%	33,9%	66,1%	38,5%	10,4%	1980 R./2004 Inc.
3	25,3%	4,6%	95,4%	25,3%	0,1%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	566.875	158.826	408.049	566.875	0	0,0001	19,80	838,8
2	12.332.026	458.827	127.986	330.841	458.827	0	0,0001	19,80	838,8
3	2.465.725	18.068	1.086	16.982	18.068	0	0,0001	19,55	809,0
4	2.175.600	108.048	30.84	77.208	108.048	0	0,0001	-20,05	798,6
5	435	10.837	776	10.061	10.837	0	0,0001	-20,05	809,0

C	P	PG	PL	P1	PX	
1	3,9%	28,0%	72,0%	3,9%	0,0%	2004 R./2004 Inc.
2	3,7%	27,9%	72,1%	3,7%	0,0%	1980 R./2004 Inc.
3	0,7%	6,0%	94,0%	0,7%	0,0%	1980 R./1980 Inc.
4	5,0%	28,5%	71,5%	5,0%	0,0%	1980 Ext. R/2004 Inc.
5	2,5%	7,2%	92,8%	2,5%	0,0%	1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	5.076.400	158.522	52.261	106.261	158.522	0	0,0001	19,80	838,8
2	2.900.800	50.474	21.421	29.053	50.474	0	0,0001	19,80	838,8
3	580	3.696	1.086	2.61	3.696	0	0,0001	19,55	809,0
4	2.175.600	108.048	30.84	77.208	108.048	0	0,0001	-20,05	798,6
5	435	10.837	776	10.061	10.837	0	0,0001	-20,05	809,0

C	P	PG	PL	P1	PX	
1	3,1%	33,0%	67,0%	3,1%	0,0%	2004 R./2004 Inc.
2	1,7%	42,4%	57,6%	1,7%	0,0%	1980 R./2004 Inc.
3	0,6%	29,4%	70,6%	0,6%	0,0%	1980 R./1980 Inc.
4	5,0%	28,5%	71,5%	5,0%	0,0%	1980 Ext. R/2004 Inc.
5	2,5%	7,2%	92,8%	2,5%	0,0%	1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.431.226	408.353	106.565	301.788	408.353	0	0,0001	41,70	804,7
2	9.431.226	408.353	106.565	301.788	408.353	0	0,0001	41,70	804,7
3	1.885.725	14.372	0	14.372	14.372	0	0,0001	74,55	1139,5
4	0	0	0	0	0	0	0,0000	0,00	0,0
5	0	0	0	0	0	0	0,0000	0,00	0,0

C	P	PG	PL	P1	PX	
1	4,3%	26,1%	73,9%	4,3%	0,0%	2004 R./2004 Inc.
2	4,3%	26,1%	73,9%	4,3%	0,0%	1980 R./2004 Inc.
3	0,8%	0,0%	100,0%	0,8%	0,0%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



Results ASTM D1250-80 with "German rounding" (Input data)

VCF - 5 decimals

### All temperature values

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.626	6.920.128	2.347.369	4.572.759	3.360.021	3.560.107	0,00006	-22,15	804,1
2	12.332.026	4.961.979	1.416.068	3.545.911	2.924.814	2.037.165	0,00005	19,90	1.143,4
3	12.332.026	4.961.979	1.416.068	3.545.911	2.924.814	2.037.165	0,00005	19,90	1.143,4
4	2.175.600	1.958.149	931.301	1.026.848	435.207	1.522.942	0,00006	-22,15	804,1
5	2.175.600	1.958.149	931.301	1.026.848	435.207	1.522.942	0,00006	-22,15	804,1

C	P	PG	PL	P1	PX	
1	47,7%	33,9%	66,1%	23,2%	24,5%	2004 R./2004 Inc.
2	40,2%	28,5%	71,5%	23,7%	16,5%	1980 R./2004 Inc.
3	40,2%	28,5%	71,5%	23,7%	16,5%	1980 R./1980 Inc.
4	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values below base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	5.076.400	4.569.602	2.229.555	2.340.047	1.015.165	3.554.437	0,00006	-22,15	804,1
2	2.900.800	2.611.453	1.298.254	1.313.199	579.958	2.031.495	0,00005	19,90	1.143,4
3	2.900.800	2.611.453	1.298.254	1.313.199	579.958	2.031.495	0,00005	19,90	1.143,4
4	2.175.600	1.958.149	931.301	1.026.848	435.207	1.522.942	0,00006	-22,15	804,1
5	2.175.600	1.958.149	931.301	1.026.848	435.207	1.522.942	0,00006	-22,15	804,1

C	P	PG	PL	P1	PX	
1	90,0%	48,8%	51,2%	20,0%	70,0%	2004 R./2004 Inc.
2	90,0%	49,7%	50,3%	20,0%	70,0%	1980 R./2004 Inc.
3	90,0%	49,7%	50,3%	20,0%	70,0%	1980 R./1980 Inc.
4	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext. R/2004 Inc.
5	90,0%	47,6%	52,4%	20,0%	70,0%	1980 Ext./1980 Inc.

### Temperature values equal to or above base

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.431.226	2.350.526	117.814	2.232.712	2.344.856	5,67	0,00002	124,45	1133,5
2	9.431.226	2.350.526	117.814	2.232.712	2.344.856	5,67	0,00002	124,45	1133,5
3	9.431.226	2.350.526	117.814	2.232.712	2.344.856	5,67	0,00002	124,45	1133,5
4	0	0	0	0	0	0	0,00000	0,00	0,0
5	0	0	0	0	0	0	0,00000	0,00	0,0

C	P	PG	PL	P1	PX	
1	24,9%	5,0%	95,0%	24,9%	0,1%	2004 R./2004 Inc.
2	24,9%	5,0%	95,0%	24,9%	0,1%	1980 R./2004 Inc.
3	24,9%	5,0%	95,0%	24,9%	0,1%	1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%	1980 Ext./1980 Inc.



VCF - 4 decimals

**All temperature values**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	14.507.62	143.377	9.003	134.374	143.377	0	0,0001	19,65	880,8
2	12.332.02	88.203	5.342	82.861	88.203	0	0,0001	19,65	880,8
3	12.332.02	88.203	5.342	82.861	88.203	0	0,0001	19,65	880,8
4	2.175.600	55.174	3.661	51.513	55.174	0	0,0001	-20,05	798,6
5	2.175.600	55.174	3.661	51.513	55.174	0	0,0001	-20,05	798,6

C	P	PG	PL	P1	PX				
1	1,0%	6,3%	93,7%	1,0%	0,0%				2004 R./2004 Inc.
2	0,7%	6,1%	93,9%	0,7%	0,0%				1980 R./2004 Inc.
3	0,7%	6,1%	93,9%	0,7%	0,0%				1980 R./1980 Inc.
4	2,5%	6,6%	93,4%	2,5%	0,0%				1980 Ext. R/2004 Inc.
5	2,5%	6,6%	93,4%	2,5%	0,0%				1980 Ext./1980 Inc.

**Temperature values below base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	5.076.400	73.803	9.003	64.8	73.803	0	0,0001	19,65	880,8
2	2.900.800	18.629	5.342	13.287	18.629	0	0,0001	19,65	880,8
3	2.900.800	18.629	5.342	13.287	18.629	0	0,0001	19,65	880,8
4	2.175.600	55.174	3.661	51.513	55.174	0	0,0001	-20,05	798,6
5	2.175.600	55.174	3.661	51.513	55.174	0	0,0001	-20,05	798,6

C	P	PG	PL	P1	PX				
1	1,5%	12,2%	87,8%	1,5%	0,0%				2004 R./2004 Inc.
2	0,6%	28,7%	71,3%	0,6%	0,0%				1980 R./2004 Inc.
3	0,6%	28,7%	71,3%	0,6%	0,0%				1980 R./1980 Inc.
4	2,5%	6,6%	93,4%	2,5%	0,0%				1980 Ext. R/2004 Inc.
5	2,5%	6,6%	93,4%	2,5%	0,0%				1980 Ext./1980 Inc.

**Temperature values equal to or above base**

C	NSC	NDF	NDG	NDL	NDD1	NDG1	MAXD	TLCB	DTLCB
1	9.431.226	69.574	0	69.574	69.574	0	0,0001	74,55	1139,5
2	9.431.226	69.574	0	69.574	69.574	0	0,0001	74,55	1139,5
3	9.431.226	69.574	0	69.574	69.574	0	0,0001	74,55	1139,5
4	0	0	0	0	0	0	0,0000	0,00	0,0
5	0	0	0	0	0	0	0,0000	0,00	0,0

C	P	PG	PL	P1	PX				
1	0,7%	0,0%	100,0%	0,7%	0,0%				2004 R./2004 Inc.
2	0,7%	0,0%	100,0%	0,7%	0,0%				1980 R./2004 Inc.
3	0,7%	0,0%	100,0%	0,7%	0,0%				1980 R./1980 Inc.
4	0,0%	0,0%	0,0%	0,0%	0,0%				1980 Ext. R/2004 Inc.
5	0,0%	0,0%	0,0%	0,0%	0,0%				1980 Ext./1980 Inc.



## Legal Notices

© Copyright 2023 QuantityWare GmbH. All rights reserved.

SAP, R/3, mySAP, mySAP.com, xApps, xApp, SAP NetWeaver, and other SAP products and services mentioned herein as well as their respective logos are trademarks or registered trademarks of SAP AG in Germany and in several other countries all over the world. All other product and service names mentioned are the trademarks of their respective companies.

Microsoft, Windows, SQL-Server, PowerPoint and Outlook are registered trademarks of Microsoft Corporation.

These materials and the information therein are subject to change without notice. These materials are provided by the company QuantityWare GmbH for informational purposes only. There is no implied representation or warranty of any kind, and QuantityWare GmbH shall not be liable for errors or omissions with respect to the materials provided. The only warranties for the products and services of QuantityWare GmbH are those set forth in the express warranty statements accompanying such products and services, if any. No statement within this document should be construed as constituting an additional warranty.